

This authorizes the application of the Certification Mark(s) shown below to the models described in the Product(s) Covered section when made in accordance with the conditions set forth in the Certification Agreement and Listing Report. This authorization also applies to multiple listee model(s) identified on the correlation page of the Listing Report.

This document is the property of Intertek Testing Services and is not transferable. The certification mark(s) may be applied only at the location of the Party Authorized To Apply Mark.

**Applicant:** SolarEdge Technologies Ltd

**Manufacturer:** Jabil Circuit (Guangzhou) LTD

**Address:** 1 Ha'Mada St.  
Herzeliya 4673335

**Address:** GUANGZHOU ECNMC & TECH  
DEV EAST DISTRICT  
128 JUN CHENG RD  
GUANGZHOU GUANGDONG 510530  
CHINA

**Country:** Israel

**Country:** China

**Party Authorized To Apply Mark:** Same as Manufacturer  
**Report Issuing Office:** Intertek Testing Services NA, Inc., Cortland, NY

**Control Number:** 4004590

**Authorized by:**

*Luger Seion*

for L. Matthew Snyder, Certification Manager



This document supersedes all previous Authorizations to Mark for the noted Report Number.

This Authorization to Mark is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Authorization to Mark. Only the Client is authorized to permit copying or distribution of this Authorization to Mark and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement and in this Authorization to Mark. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.

Intertek Testing Services NA Inc.  
545 East Algonquin Road, Arlington Heights, IL 60005  
Telephone 800-345-3851 or 847-439-5667 Fax 312-283-1672

<b>Standard(s):</b>	Inverters, Converters, Controllers and Interconnection System Equipment for use with Distributed Energy Resources [UL 1741:2021 Ed.3] Power Conversion Equipment [CSA C22.2#107.1:2016 Ed.4] Photovoltaic Rapid Shutdown Systems [CSA C22.2#330:2017 Ed.1]
<b>Product:</b>	Power Box and Power Optimizer
<b>Brand Name:</b>	SolarEdge

**Models:**

PB followed by 001 to 350; followed by -AOB or -TFI.  
OP followed by 001 to 500; followed by -LV, -MV, -IV or -EV.  
P followed by 001 to 1101.  
SP followed by 001 to 350.  
S followed by 001 to 500; may be followed by A.  
S followed by 001 to 1401; may be followed by B.  
H followed by 0001 to 1300.  
R followed by 0001 to 1401

This authorizes the application of the Certification Mark(s) shown below to the models described in the Product(s) Covered section when made in accordance with the conditions set forth in the Certification Agreement and Listing Report. This authorization also applies to multiple listee model(s) identified on the correlation page of the Listing Report.

This document is the property of Intertek Testing Services and is not transferable. The certification mark(s) may be applied only at the location of the Party Authorized To Apply Mark.

**Applicant:** SolarEdge Technologies Ltd

**Manufacturer:** Flextronics ZALA

**Address:** 1 Ha'Mada St.  
Herzeliya 4673335

**Address:** Posta u.63  
Zalaegerszeg  
8900

**Country:** Israel

**Country:** Hungary

**Party Authorized To Apply Mark:** Same as Manufacturer

**Report Issuing Office:** Intertek Testing Services NA, Inc., Cortland, NY

**Control Number:** 4004590

**Authorized by:**



for L. Matthew Snyder, Certification Manager



This document supersedes all previous Authorizations to Mark for the noted Report Number.

This Authorization to Mark is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Authorization to Mark. Only the Client is authorized to permit copying or distribution of this Authorization to Mark and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement and in this Authorization to Mark. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.

Intertek Testing Services NA Inc.  
545 East Algonquin Road, Arlington Heights, IL 60005  
Telephone 800-345-3851 or 847-439-5667 Fax 312-283-1672

<b>Standard(s):</b>	Inverters, Converters, Controllers and Interconnection System Equipment for use with Distributed Energy Resources [UL 1741:2021 Ed.3]  Power Conversion Equipment [CSA C22.2#107.1:2016 Ed.4]  Photovoltaic Rapid Shutdown Systems [CSA C22.2#330:2017 Ed.1]
<b>Product:</b>	Power Box and Power Optimizer
<b>Brand Name:</b>	SolarEdge

**Models:**

PB followed by 001 to 350; followed by -AOB or -TFI.  
OP followed by 001 to 500; followed by -LV, -MV, -IV or -EV.  
P followed by 001 to 1101.  
SP followed by 001 to 350.  
S followed by 001 to 500; may be followed by A.  
S followed by 001 to 1401; may be followed by B.  
H followed by 0001 to 1300.  
R followed by 0001 to 1401

This authorizes the application of the Certification Mark(s) shown below to the models described in the Product(s) Covered section when made in accordance with the conditions set forth in the Certification Agreement and Listing Report. This authorization also applies to multiple listee model(s) identified on the correlation page of the Listing Report.

This document is the property of Intertek Testing Services and is not transferable. The certification mark(s) may be applied only at the location of the Party Authorized To Apply Mark.

**Applicant:** SolarEdge Technologies Ltd

**Manufacturer:** SolarEdge Technologies Inc

**Address:** 1 Ha'Mada St.  
Herzeliya 4673335

**Address:** 447 Ingenuity Avenue Suite 120, Bldg. B,  
Sparks, NV 89441

**Country:** Israel

**Country:** USA

**Party Authorized To Apply Mark:** Same as Manufacturer  
**Report Issuing Office:** Intertek Testing Services NA, Inc., Cortland, NY

**Control Number:** 4004590

**Authorized by:**



for L. Matthew Snyder, Certification Manager



This document supersedes all previous Authorizations to Mark for the noted Report Number.

This Authorization to Mark is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Authorization to Mark. Only the Client is authorized to permit copying or distribution of this Authorization to Mark and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement and in this Authorization to Mark. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.

Intertek Testing Services NA Inc.  
545 East Algonquin Road, Arlington Heights, IL 60005  
Telephone 800-345-3851 or 847-439-5667 Fax 312-283-1672

<b>Standard(s):</b>	Inverters, Converters, Controllers and Interconnection System Equipment for use with Distributed Energy Resources [UL 1741:2021 Ed.3] Power Conversion Equipment [CSA C22.2#107.1:2016 Ed.4] Photovoltaic Rapid Shutdown Systems [CSA C22.2#330:2017 Ed.1]
<b>Product:</b>	Power Box and Power Optimizer
<b>Brand Name:</b>	SolarEdge

**Models:**

PB followed by 001 to 350; followed by -AOB or -TFI.  
OP followed by 001 to 500; followed by -LV, -MV, -IV or -EV.  
P followed by 001 to 1101.  
SP followed by 001 to 350.  
S followed by 001 to 500; may be followed by A.  
S followed by 001 to 1401; may be followed by B.  
H followed by 0001 to 1300.  
R followed by 0001 to 1401

This authorizes the application of the Certification Mark(s) shown below to the models described in the Product(s) Covered section when made in accordance with the conditions set forth in the Certification Agreement and Listing Report. This authorization also applies to multiple listee model(s) identified on the correlation page of the Listing Report.

This document is the property of Intertek Testing Services and is not transferable. The certification mark(s) may be applied only at the location of the Party Authorized To Apply Mark.

**Applicant:** SolarEdge Technologies Ltd

**Manufacturer:** Jabil Vietnam Co. Ltd.

**Address:** 1 Ha'Mada St.  
Herzeliya 4673335

**Address:** Lot i8-1, Saigon Hi-tech Park, District 9,  
HCM City, Vietnam, 70000

**Country:** Israel

**Country:** Vietnam

**Party Authorized To Apply Mark:** Same as Manufacturer

**Report Issuing Office:** Intertek Testing Services NA, Inc., Cortland, NY

**Control Number:** 4004590

**Authorized by:**

*Lugei Seion*

for L. Matthew Snyder, Certification Manager



This document supersedes all previous Authorizations to Mark for the noted Report Number.

This Authorization to Mark is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Authorization to Mark. Only the Client is authorized to permit copying or distribution of this Authorization to Mark and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement and in this Authorization to Mark. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.

Intertek Testing Services NA Inc.  
545 East Algonquin Road, Arlington Heights, IL 60005  
Telephone 800-345-3851 or 847-439-5667 Fax 312-283-1672

<b>Standard(s):</b>	Inverters, Converters, Controllers and Interconnection System Equipment for use with Distributed Energy Resources [UL 1741:2021 Ed.3]  Power Conversion Equipment [CSA C22.2#107.1:2016 Ed.4]  Photovoltaic Rapid Shutdown Systems [CSA C22.2#330:2017 Ed.1]
<b>Product:</b>	Power Box and Power Optimizer
<b>Brand Name:</b>	SolarEdge

**Models:**

PB followed by 001 to 350; followed by -AOB or -TFI.  
OP followed by 001 to 500; followed by -LV, -MV, -IV or -EV.  
P followed by 001 to 1101.  
SP followed by 001 to 350.  
S followed by 001 to 500; may be followed by A.  
S followed by 001 to 1401; may be followed by B.  
H followed by 0001 to 1300.  
R followed by 0001 to 1401



This authorizes the application of the Certification Mark(s) shown below to the models described in the Product(s) Covered section when made in accordance with the conditions set forth in the Certification Agreement and Listing Report. This authorization also applies to multiple listee model(s) identified on the correlation page of the Listing Report.

This document is the property of Intertek Testing Services and is not transferable. The certification mark(s) may be applied only at the location of the Party Authorized To Apply Mark.

**Applicant:** SolarEdge Technologies Ltd

**Manufacturer:** Solaredge Sella1

**Address:** 1 Ha'Mada St.  
Herzeliya 4673335

**Address:** 2 Hamerkava St. PO Box 70004 Ziporit  
Industrial Zone  
Nof Hagalil, 1789058

**Country:** Israel

**Country:** Israel

**Party Authorized To Apply Mark:** Same as Manufacturer  
**Report Issuing Office:** Intertek Testing Services NA, Inc., Cortland, NY

**Control Number:** 4004590

**Authorized by:**

*Luger Seion*

for L. Matthew Snyder, Certification Manager



This document supersedes all previous Authorizations to Mark for the noted Report Number.

This Authorization to Mark is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Authorization to Mark. Only the Client is authorized to permit copying or distribution of this Authorization to Mark and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement and in this Authorization to Mark. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.

Intertek Testing Services NA Inc.  
545 East Algonquin Road, Arlington Heights, IL 60005  
Telephone 800-345-3851 or 847-439-5667 Fax 312-283-1672

<b>Standard(s):</b>	Inverters, Converters, Controllers and Interconnection System Equipment for use with Distributed Energy Resources [UL 1741:2021 Ed.3] Power Conversion Equipment [CSA C22.2#107.1:2016 Ed.4] Photovoltaic Rapid Shutdown Systems [CSA C22.2#330:2017 Ed.1]
<b>Product:</b>	Power Box and Power Optimizer
<b>Brand Name:</b>	SolarEdge

**Models:**

PB followed by 001 to 350; followed by -AOB or -TFI.  
OP followed by 001 to 500; followed by -LV, -MV, -IV or -EV.  
P followed by 001 to 1101.  
SP followed by 001 to 350.  
S followed by 001 to 500; may be followed by A.  
S followed by 001 to 1401; may be followed by B.  
H followed by 0001 to 1300.  
R followed by 0001 to 1401

This authorizes the application of the Certification Mark(s) shown below to the models described in the Product(s) Covered section when made in accordance with the conditions set forth in the Certification Agreement and Listing Report. This authorization also applies to multiple listee model(s) identified on the correlation page of the Listing Report.

This document is the property of Intertek Testing Services and is not transferable. The certification mark(s) may be applied only at the location of the Party Authorized To Apply Mark.

**Applicant:** SolarEdge Technologies Ltd

**Manufacturer:** SolarEdge Technologies Inc

**Address:** 1 Ha'Mada St.  
Herzeliya 4673335

**Address:** 700 E. Tasman Drive,  
Milpitas, Ca 95035

**Country:** Israel

**Country:** USA

**Party Authorized To Apply Mark:** Same as Manufacturer  
**Report Issuing Office:** Intertek Testing Services NA, Inc., Cortland, NY

**Control Number:** 4004590

**Authorized by:**

*L. Matthew Snyder*

for L. Matthew Snyder, Certification Manager



This document supersedes all previous Authorizations to Mark for the noted Report Number.

This Authorization to Mark is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Authorization to Mark. Only the Client is authorized to permit copying or distribution of this Authorization to Mark and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement and in this Authorization to Mark. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.

Intertek Testing Services NA Inc.  
545 East Algonquin Road, Arlington Heights, IL 60005  
Telephone 800-345-3851 or 847-439-5667 Fax 312-283-1672

<b>Standard(s):</b>	Inverters, Converters, Controllers and Interconnection System Equipment for use with Distributed Energy Resources [UL 1741:2021 Ed.3] Power Conversion Equipment [CSA C22.2#107.1:2016 Ed.4] Photovoltaic Rapid Shutdown Systems [CSA C22.2#330:2017 Ed.1]
<b>Product:</b>	Power Box and Power Optimizer
<b>Brand Name:</b>	SolarEdge

**Models:**

PB followed by 001 to 350; followed by -AOB or -TFI.  
OP followed by 001 to 500; followed by -LV, -MV, -IV or -EV.  
P followed by 001 to 1101.  
SP followed by 001 to 350.  
S followed by 001 to 500; may be followed by A.  
S followed by 001 to 1401; may be followed by B.  
H followed by 0001 to 1300.  
R followed by 0001 to 1401

This authorizes the application of the Certification Mark(s) shown below to the models described in the Product(s) Covered section when made in accordance with the conditions set forth in the Certification Agreement and Listing Report. This authorization also applies to multiple listee model(s) identified on the correlation page of the Listing Report.

This document is the property of Intertek Testing Services and is not transferable. The certification mark(s) may be applied only at the location of the Party Authorized To Apply Mark.

**Applicant:** SolarEdge Technologies Ltd

**Manufacturer:** Flextronics Manufacturing Mex, S.A de C.V.

**Address:** 1 Ha'Mada St.  
Herzeliya 4673335

**Address:** Carretara base aerea #5850-12 Col. La mora Zapopan Jalisco, Mexico C.P. 45136

**Country:** Israel

**Country:** Mexico

**Party Authorized To Apply Mark:** Same as Manufacturer

**Report Issuing Office:** Intertek Testing Services NA, Inc., Cortland, NY

**Control Number:** 4004590

**Authorized by:**



for L. Matthew Snyder, Certification Manager



This document supersedes all previous Authorizations to Mark for the noted Report Number.

This Authorization to Mark is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Authorization to Mark. Only the Client is authorized to permit copying or distribution of this Authorization to Mark and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement and in this Authorization to Mark. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.

Intertek Testing Services NA Inc.  
545 East Algonquin Road, Arlington Heights, IL 60005  
Telephone 800-345-3851 or 847-439-5667 Fax 312-283-1672

<b>Standard(s):</b>	Inverters, Converters, Controllers and Interconnection System Equipment for use with Distributed Energy Resources [UL 1741:2021 Ed.3]  Power Conversion Equipment [CSA C22.2#107.1:2016 Ed.4]  Photovoltaic Rapid Shutdown Systems [CSA C22.2#330:2017 Ed.1]
<b>Product:</b>	Power Box and Power Optimizer
<b>Brand Name:</b>	SolarEdge

**Models:**

PB followed by 001 to 350; followed by -AOB or -TFI.  
OP followed by 001 to 500; followed by -LV, -MV, -IV or -EV.  
P followed by 001 to 1101.  
SP followed by 001 to 350.  
S followed by 001 to 500; may be followed by A.  
S followed by 001 to 1401; may be followed by B.  
H followed by 0001 to 1300.  
R followed by 0001 to 1401

This authorizes the application of the Certification Mark(s) shown below to the models described in the Product(s) Covered section when made in accordance with the conditions set forth in the Certification Agreement and Listing Report. This authorization also applies to multiple listee model(s) identified on the correlation page of the Listing Report.

This document is the property of Intertek Testing Services and is not transferable. The certification mark(s) may be applied only at the location of the Party Authorized To Apply Mark.

<b>Applicant:</b>	SolarEdge Technologies Ltd	<b>Manufacturer:</b>	Jabil Circuit (Guangzhou) Ltd. Dongyuan Sub-Branch
<b>Address:</b>	1 Ha'Mada St. Herzeliya 4673335	<b>Address:</b>	NO. 1 Dongyuan Road, Huangpu District, Guangzhou, Guangdong Province
<b>Country:</b>	Israel	<b>Country:</b>	China
<b>Party Authorized To Apply Mark:</b>	Same as Manufacturer		
<b>Report Issuing Office:</b>	Intertek Testing Services NA, Inc., Cortland, NY		
<b>Control Number:</b>	<b>4004590</b>	<b>Authorized by:</b>	

for L. Matthew Snyder, Certification Manager



This document supersedes all previous Authorizations to Mark for the noted Report Number.

This Authorization to Mark is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Authorization to Mark. Only the Client is authorized to permit copying or distribution of this Authorization to Mark and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement and in this Authorization to Mark. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.

Intertek Testing Services NA Inc.  
545 East Algonquin Road, Arlington Heights, IL 60005  
Telephone 800-345-3851 or 847-439-5667 Fax 312-283-1672

<b>Standard(s):</b>	Inverters, Converters, Controllers and Interconnection System Equipment for use with Distributed Energy Resources [UL 1741:2021 Ed.3]  Power Conversion Equipment [CSA C22.2#107.1:2016 Ed.4]  Photovoltaic Rapid Shutdown Systems [CSA C22.2#330:2017 Ed.1]
<b>Product:</b>	Power Box and Power Optimizer
<b>Brand Name:</b>	SolarEdge

**Models:**

PB followed by 001 to 350; followed by -AOB or -TFI.  
OP followed by 001 to 500; followed by -LV, -MV, -IV or -EV.  
P followed by 001 to 1101.  
SP followed by 001 to 350.  
S followed by 001 to 500; may be followed by A.  
S followed by 001 to 1401; may be followed by B.  
H followed by 0001 to 1300.  
R followed by 0001 to 1401