

Certificate of Conformity

By the product certificate number:

No. 2621/0429-E-E1-CER

Issued to:

License holder: **SolarEdge Technologies, Ltd.**
1 Hamada street Herzliya Pituach, 4673335 (Israel)

Trademark:

solaredge

Factory location: **SolarEdge Technologies, Ltd.**
2 Hamerkava street, industrial Zone, Tziporit, Israel

It is certified that the product:

Type of generating unit: **Three-Phase Photovoltaic Inverter**

Model:

SE330K

Technical Data:

Nominal power

330 kW

Nominal voltage

690 V_{ac}

Nominal frequency

50 / 60 Hz

Firmware version

2.3.132

Number of phases

**Three Phase
(3/N/PE)**

Isolation Transformer

No

Is in compliance with the standard:

- **Engineering Recommendation G99. Issue 1, Amendment 10. March 2024:**
Requirements for the connection of generation equipment in parallel with public distribution networks on or after 27 April 2019.
- **Engineering Recommendation G99/N1. Issue 1, Amendment 1. December 2023:**
Requirements for the connection of generation equipment in parallel with public distribution networks on or after 27 April 2019.

It is certified that the Power Generating Units-indicated are in compliance with requirements detailed in the above-referenced standard for grid connections of Type A, B, C and D.

This certificate is based upon the test results of the Test Report No. 2221 / 0429 - E - E1 & 2221 / 0429 – E01. The testing process has been carried out according the SGS internal procedure PE.T-LE-62 based on the requirements of the UNE-EN ISO / IEC 17025.

The above-mentioned generating unit is certified according to the SGS internal procedure PROCESO 4 based on the requirements of the UNE-EN ISO/IEC 17065.

This certificate cancels and supersedes certificate No. 2621/0429-E-CER

First issued on: 27th February 2025.

This certificate is valid until: 16th January 2030.

Madrid, 27th February 2025


Daniel Arranz Muñiz
Certification Manager

