

Verification of Conformity

Verification Number: 105602966CRT-001-VOC

On the basis of the tests undertaken, the sample of the below product have been found to comply with the requirements of the referenced standards at the time the tests were carried out. This verification is part of the full test report and should be read in conjunction with it.

Applicant Name & Address:	SolarEdge Technologies Ltd. 1 Hamada St., Herzeliya, 4673335 Israel
Product Description:	Revenue Grade meter
Ratings:	120-480 V, Current Class 50-600A, Accuracy Class 0.5 (see datasheet for detail)
Models/Type References:	SE-RGMTR-1D-240C-A Current Class 50 SE-RGMTR-1D-240C-B Current Class 50 SE-RGMTR-3D-208V-A Current Class 150, 300 & 600 SE-RGMTR-3Y-208V-A Current Class 150, 300 & 600 SE-RGMTR-3Y-480V-A Current Class 150, 300 & 600 SE-RGMTR-1D-240C-C
Brand Names/Firmware version:	SolarEdge/ 0.7
Specification<s>/Standards:	ANSI C12.20:2015 American National Standard for Electricity Meters—0.1, 0.2, And 0.5 Accuracy Classes. ANSI C12.1:2016Ed.2014 American National Standard for Electric Meters Code for Electricity Metering.
Verification Issuing Office Name & Address:	Intertek Testing Services NA, Inc., 3933 US Route 11, Cortland, NY 13045 USA
Date of Tests:	07/30/19 - 1/2/2024.
Test Report Number(s):	103698586CRT-001, 103698586CRT-001a, 103698586CRT-001b, 103698586CRT-001c, 103698586CRT-001d & 103698586BOX-001.5.



Signature

Name: Burl Bhalla

Position: Project Engineer

Date: 6-March-2024

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.