



Product Service

CERTIFICATE

No. B 13 01 82496 003

Holder of Certificate: SolarEdge Technologies6 HeHarash St
Hod Hasharon
ISRAEL**Production
Facility(ies):**

51369, 82959

Certification Mark:**Product:**Connecting cabinets
(Junction box with DC to DC power optimizer)**Model(s):**OPJxxx-LV (Where xxx=250-330, which
stands for the rated output power xxx W)**Parameters:**

Rated voltage:	1000 V d.c.
Rated input current:	10 A
Rated output current:	15 A
Rated output power:	250 W - 330 W
Application class:	A
Protection class:	II
Degree of protection:	IP67
Ambient temperature:	-40 °C to +85 °C

Tested according to: EN 50548:2011
EN 62109-1:2010

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

Test report no.: 64290120142002**Date,** 2013-01-24
Page 1 of 1

Frank Zhu
(Frank Zhu)

