



A P P R O V A L S ®

Certificate of Suitability

Addendum

Certificate No.: SAA170154

Date of Issue: 2 October 2020

Regulatory Definition: Non-Declared
Product Description: PV MPP Optimizer

General Modification:

For model P950:

Output rating changed from 5-85Vdc 17A 950W to 5-80Vdc 18A 950W.

Additional Models	Trade Name	Rating/Marking
P960	Solaredge	Input: 12.5-60Vdc, 11A Output: 5-80Vdc 18A 960W Ta=65°C, IP65, Class II

R. A. Hill

For and on Behalf of
SAA Approvals Pty Ltd

This certificate is issued by SAA Approvals Pty Ltd in accordance with the SAA Approvals Electrical Product Safety Certification Scheme accredited by JAS-ANZ under AS/NZS ISO/IEC 17065. SAA certifies the product nominated in this certificate complies with standard/s listed above in accordance with the scheme herein.

For SAA Contact Details and to verify this Certificate go to:

www.saaapprovals.com.au



www.jas-anz.org/register



Issued: 02-10-20 170154/7