

TUV SUD TUV SUD TUV SUD TUV SUD TUV SUD TUV SUD TUV SUD TUV SUD TUV SUD TUV SUD TUV SUD TUV SUD TUV SUD TUV SUD
ZERTIFIKAT ♦ CERTIFICATE ♦ 認證證書 ♦ CERTIFICADO ♦ CERTIFIKAT ♦ CERTIFIKAT ♦ CERTIFICATE



Product Service

CERTIFICATE

No. Z2 082496 0007 Rev. 00

Holder of Certificate: SolarEdge Technologies Ltd.

1 Hamada Street
 4673335 Herzeliya
 ISRAEL

Certification Mark:



Product:

**Crystalline Silicon Terrestrial Photovoltaic (PV) Modules
 Mono-Crystalline Silicon Photovoltaic Module**

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

Test report no.: 701262005001-00

Valid until: 2025-03-18

Date, 2020-05-07 (Zhulin Zhang)



Product Service

CERTIFICATE

No. Z2 082496 0007 Rev. 00

Model(s):

PVxxx-R60L BMC (xxx=300-320, in step of 5);
SPVxxx-R60L BMC (xxx=300-320, in step of 5);
PVxxx-R72L BMC (xxx=360-385, in step of 5);
SPVxxx-R72L BMC (xxx=360-385, in step of 5);
PVxxx-R60L BMG (xxx=335-365, in step of 5);
SPVxxx-R60L BMG (xxx=335-365, in step of 5);
PVxxx-R72L BMG (xxx=405-425, in step of 5);
SPVxxx-R72L BMG (xxx=405-425, in step of 5);
xxx is standing for rated output power at STC.

Parameters:

Fire Safety Class:	Class C according to UL790.
Safety Class:	Class II
Max. System Voltage:	1000V DC
Test Laboratory:	Yangzhou Opto-Electrical Products Testing Institute. No.10 West Kaifa Road, Yangzhou 225009 Jiangsu, P.R.China.
Construction:	Framed, with Junction box, Cable and connector.

Tested according to:

IEC 61215-1(ed.1)
IEC 61215-1-1(ed.1)
IEC 61215-2(ed.1)
IEC 61730-1(ed.2)
IEC 61730-2(ed.2)
EN 61215-1:2016
EN 61215-1-1:2016
EN 61215-2:2017
EN IEC 61730-1:2018
EN IEC 61730-1:2018/AC:2018-06
EN IEC 61730-2:2018
EN IEC 61730-2:2018/AC:2018-06

Production Facility(ies):

001192, 099605, 099626, 102892