



Product Service

Compliance Document

No. D 082496 0048 Rev. 00

Holder of Certificate: **SolarEdge Technologies Ltd.**
1 Hamada Street
4673335 Herzeliya
ISRAEL

Product: **Converter**
(Energy Storage Inverter with storage battery system)

Model(s): **Inverter model: PCS050**
Battery system model: CSS-OU-20

Parameters: See page 2

Tested according to: CEI 0-16:2022
CEI 0-16:2022/V1:2022
CEI 0-16:2022/V2:2023
CEI 0-16:2022/V3:2024

This Compliance document confirms the compliance with the listed standards on a voluntary basis. It refers only to the sample submitted for testing and certification and does not certify the quality or safety of the serial products. For details see: www.tuvsud.com/ps-cert

Test report no.: 64290243052401

Date, 2024-10-11

(Billy Qiu)



Product Service

Compliance Document

No. D 082496 0048 Rev. 00

Parameters:

Inverter model	PCS050
Battery input/output parameters	
Battery type	LiFePO4
Maximum voltage [V _{DC}]	750
Battery rated voltage [V _{DC}]	512
Battery voltage range [V _{DC}]	350 - 750
Maximum charge power [W]	55000
Maximum discharge power [W]	55000
Maximum charge current [A _{DC}]	55/55
Maximum discharge current [A _{DC}]	55/55
Grid terminal input parameters	
Rated input voltage [V _{AC}]	3P+N+PE, 230/400
Rated input frequency [Hz]	50
Maximum continuous input current from grid to battery [A _{AC}]	72
Maximum continuous input current [A _{AC}]	80
Maximum continuous input power from grid to battery [W]	50000
Maximum continuous input active power [W]	50000
Maximum continuous input apparent power [VA]	55000
Power factor range	0.9 inductive to 0.9 capacitive
Grid terminal output parameters	
Rated output voltage [V _{AC}]	3P+N+PE, 230/400
Rated output frequency [Hz]	50
Rated output current [A _{AC}]	72
Maximum continuous output current [A _{AC}]	80
Rated output active power [W]	50000
Maximum output active power [W]	50000
Maximum output apparent power [VA]	55000
Power factor range	0.9 inductive to 0.9 capacitive

Battery model parameters see below page: 3



Product Service

Compliance Document

No. D 082496 0048 Rev. 00

The following generators meet the requirements of CEI 0-16:2022, CEI 0-16:2022/V1:2022, CEI 0-16:2022/V2:2023 and CEI 0-16:2022/V3:2024		
Section A	Manufacturer	SolarEdge Technologies Ltd. 1 Hamada Street 4673335 Herzeliya ISRAEL
	Equipment type	Energy Storage Inverter with storage battery system
	Brand	SolarEdge
	User side connection	<input checked="" type="checkbox"/> Three-phase with neutral <input type="checkbox"/> Three-phase without neutral Frequency: 50 Hz Voltage: 230/400 V _{AC}
	Primary energy used	<input type="checkbox"/> Solar <input checked="" type="checkbox"/> Storage <input type="checkbox"/> Wind <input type="checkbox"/> Hydroelectric <input type="checkbox"/> CHP <input type="checkbox"/> Other:
	Generator model	PCS050
	Rated active power output to Grid	50000 W
	Maximum apparent power output to Grid	55000 VA
	The generator:	<input checked="" type="checkbox"/> suitable for installation in plants with a power output of less than or equal to 400 kW <input checked="" type="checkbox"/> suitable for installation in plants with a power exceeding 400 kW
Section B	Static converter characteristics	
	Manufacturer of inverter	SolarEdge Technologies Ltd.
	Firmware version	V000B000D001
	Model of inverter	PCS050
	Nominal converter power (P _{NINV})	50000 W
Section D	Characteristics of the Storage System (SdA)	
	Batteries that can be used with the above static converters	
	Brand	SolarEdge
	Technology	LiFePO4
	Models	CSS-OU-20
	CUS module (kWh)	102.4 (with 1 × battery system CSS-OU-20, one battery system includes total 20 battery module EM-5.1K01 (2P10S) in series)
	BMS firmware version	BAU V3001.31.12.0, BCU V3301.21.12.0, CSU V101.11.0
	Number of modules	1-2 CSS-OU-20
	Note	Batteries are not contained in the inverter and should be installed according to local regulations and in accordance with manufacturer's instruction.



Product Service

Compliance Document

No. D 082496 0048 Rev. 00

Section H	References of the laboratories that performed the tests and their test reports (RdP)	
	Selected method	<input checked="" type="checkbox"/> Tests performed by an accredited laboratory
	Test Reports (RdP)	Test report according to Annex Nbis: 64.290.24.30524.01
	Issued by	Accredited lab: TÜV SÜD Certification and Testing (China) Co., Ltd. Guangzhou Branch
	Accreditation No.	D-PL-19065-01-00
	Accreditation body ref.	DAkkS
Section L	Reference of the certification body	
	Certification Body	TÜV SÜD Product Service GmbH
		DAkkS accreditation certificate D-ZE-11321-01-00 according to DIN EN ISO/IEC 17065:2013