

Ref. Certif. No.

DE/PTZ/0197/A4

## IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME **CB TEST CERTIFICATE** Product Inline Energy Meter Name and address of the applicant SolarEdge Technologies LTD 1 HaMada Street 4673335 Herzeliya Israel SolarEdge Technologies LTD 1 HaMada Street Name and address of the manufacturer 4673335 Herzeliya Israel Name and address of the factory SolarEdge Technologies LTD 1 HaMada Street Note: When more than one factory, please report on page 2 4673335 Herzeliya Israel Additional information on page 2 Ratings and principal characteristics MTR-EU1: 1x230/400 Vac; 45-65 Hz; 0,25-65A; MTR-EU3: 3x230/400 Vac; 45-65 Hz; 0,25-65A; SolarEdge Trademark (if any) Customer's Testing Facility (CTF) Stage used Model / Type Ref. MTR-EU1; MTR-EU3 This CBTC replaces the previously issued CBTC ref. cert. no. DE/PTZ/0197/ Additional information (if necessary may also be reported on page 2) A3, dated 2022-04-07. New revision of test report. Additional information on page 2 A sample of the product was tested and found to be in IEC 61010-1:2010, IEC 61010-1:2010/AMD1:2016 conformity with National differences: **EU Group Differences** As shown in the Test Report Ref. No. which forms part 20PP112-01\_4 of this Certificate

This CB Test Certificate is issued by the National Certification Body

Kiwa Primara GmbH Gewerbestraße 28 Kaufbeuren, 87600 Germany



Signature: Tanja Rottach