



# Certificate of compliance

**Applicant:** SolarEdge Technologies Ltd.  
1 HaMada Street  
Herzliya 4673335  
Israel

**Product:** Photovoltaic (PV) and battery inverter (Hybrid-System)

**Model:** SE5K-RWB48  
SE7K-RWB48  
SE8K-RWB48  
SE10K-RWB48

Inverter for three-phase parallel connection to the public grid. The network monitoring and disconnection device is an integral part of the above-mentioned model.

## Applied rules and standards:

### Green Power Denmark:2022

Guide for connection of power-generating plants to the low-voltage grid ( $\leq 1\text{kV}$ )  
Plant category A plant up to 125kW

- 4. Requirements for Type A power-generating plants
- 4.1 Tolerance of Frequency and voltage deviations
- 4.2 Start-up and reconnection of a power-generating plant
- 4.3 Active power control
- 4.4 Reactive power control
- 4.5 Protection
- 4.6 Power Quality
- 4.7 Exchange of Information

### DIN VDE V 0124-100:2020 (5.5.2.1 Functional safety of network and system protection)

Grid integration of generator plants - Low-voltage - Test requirements for generator units to be connected to and operated in parallel with low-voltage distribution networks

At the time of issue of this certificate, the safety concept of an aforementioned representative product corresponds to the valid safety specifications for the specified use in accordance with regulations.

**Report number:** 22TH0188-GPD-LV-DK1-DK2\_0      **Certification Program:** NSOP-0032-DEU-ZE-V01  
**Certificate number:** U23-1006      **Date of issue:** 2023-12-04

## Certification body



Certification body Bureau Veritas Consumer Products Services Germany GmbH accreditation to DIN EN ISO/IEC 17065

Testing laboratory accredited according to DIN EN ISO/IEC 17025

A partial representation of the certificate requires the written approval of Bureau Veritas Consumer Products Services Germany GmbH

## Type Verification Test Report

Extract from test report according to Green Power Denmark

No. 22TH0188-GPD-LV-DK1-DK2\_0

### Type Approval and declaration of compliance with the requirements of Green Power Denmark

<b>Manufacturer / applicant</b>	SolarEdge Technologies Ltd. 1 HaMada Street Herzliya 4673335 Israel
---------------------------------	--

<b>Micro-generator Type</b>	Photovoltaic (PV) and battery inverter
-----------------------------	--

	SE5K-RWB48	SE7K-RWB48	SE8K-RWB48	SE10K-RWB48
<b>Photovoltaic (DC)</b>				
<b>Max DC voltage [V]</b>	750 – 900	750 – 900	750 – 900	750 – 900
<b>Input DC current [A]</b>	13,3	16,0	17,3	20,0
<b>Battery (DC)</b>				
<b>Battery DC voltage range [V]</b>	40 – 62	40 – 62	40 – 62	40 – 62
<b>Battery charge current [A]</b>	130	130	130	130
<b>Battery discharge current [A]</b>	130	130	130	130
<b>Connection (AC)</b>				
<b>Output AC voltage [V]</b>	220/230 L-N 380/400 L-L 50 / 60 Hz	220/230 L-N 380/400 L-L 50 / 60 Hz	220/230 L-N 380/400 L-L 50 / 60 Hz	220/230 L-N 380/400 L-L 50 / 60 Hz
<b>Max AC current [A]</b>	8,0	11,5	13,0	16,0
<b>Active Power [W]</b>	5000	7000	8000	10000
<b>Apparent power [VA]</b>	5000	7000	8000	10000
<b>Type</b>	Bidirectional	Bidirectional	Bidirectional	Bidirectional

<b>Firmware version</b>	Main DSP 1.20 AUX DSP 2.20
-------------------------	-------------------------------

### Batteries are used in the above stated storage system

<b>Brand</b>	Solaredge Technologies GmbH	--	--	--
<b>Technology</b>	Li-Ion - LFP	--	--	--
<b>Model</b>	BAT-05K48	--	--	--
<b>CUS module (kWh)</b>	4,6	--	--	--
<b>Firmware version of the BMS</b>	BMS 1.1260.0	--	--	--
<b>Number of modules</b>	1-5 (1, 2, 3, 4, 5)	--	--	--

### Description of the structure of the power generation unit:

The power generation unit is equipped with a PV/DC and line-side EMC filter. The power generation unit has no galvanic isolation between DC input and AC output. Output switch-off is performed with single-fault tolerance based on two series-connected relays in each line and neutral. This enables a safe disconnection of the power generation unit from the network in case of error.

Type Verification Test Report

Extract from test report according to Green Power Denmark

No. 22TH0188-GPD-LV-DK1-DK2\_0

Setting of the parameter values for DK1 and DK2		
	Settings for DK1	Setting for DK2
	LFSM-O	
Threshold frequency [Hz]	50,2	50,5
Droop [% of P <sub>n</sub> ]	5% (40% P <sub>n</sub> /Hz)	4% (50% P <sub>n</sub> /Hz)
Intentional Delay	500ms	500ms
	Reactive Power	
	Q fix	Q fix
Active/disabled [On/Off]	On	On
Q setpoint [VAr]	0	0
	cos $\phi$ fix	
Active/disabled [On/Off]	Off	Off
PF setpoint [PF]	1	1
	cos $\phi$ (P)	
Active/disabled [On/Off]	Off	Off
Cos $\phi$ (P) P1 [% of P <sub>n</sub> ]	0	0
Cos $\phi$ (P) PF1 [PF]	1	1
Cos $\phi$ (P) P2 [% of P <sub>n</sub> ]	50	50
Cos $\phi$ (P) PF2 [PF]	1	1
Cos $\phi$ (P) P3 [% of P <sub>n</sub> ]	100	100
Cos $\phi$ (P) PF3 [PF]	0,9 inductive	0,9 inductive
Cos $\phi$ (P) Lockin [% of U <sub>n</sub> ]	105	105
Cos $\phi$ (P) Lockout [% of U <sub>n</sub> ]	100	100
	Connection and Reconnection	
Gradient [% of P <sub>n</sub> /min]	20	20
Observation time [seconds]	180	180
U <sub>min</sub> [% of U <sub>n</sub> ]	85	85
U <sub>max</sub> [% of U <sub>n</sub> ]	110	110
f <sub>min</sub> [Hz]	47,5	47,5
f <sub>max</sub> [Hz]	50,2	50,5

**Type Verification Test Report**

Extract from test report according to Green Power Denmark

No. 22TH0188-GPD-LV-DK1-DK2\_0

	Settings for DK1	Setting for DK2
	<b>System Protection</b>	
f> [s]	0,2	0,2
f> [Hz]	51,5	51,5
f< [s]	0,2	0,2
f< [Hz]	47,5	47,5
U> [s]	60	60
U> [% of U <sub>n</sub> ]	110	110
U>> [s]	0,2	0,2
U>> [% of U <sub>n</sub> ]	115	115
U< [s]	50	50
U< [% of U <sub>n</sub> ]	85	85
	<b>Loss of Mains Detection</b>	
U<< [s]	0,2	0,2
U<< [% of U <sub>n</sub> ]	80	80

**Note**

The settings of the interface protection are password protected adjustable.

In case the above stated generators are used with an external protection device, the protection settings of the inverters are to be adjusted according to the manufacturer's declaration.