

Test Verification of Conformity

Verification Number: 105405506CRT-001VOC

On the basis of the tests undertaken, the samples of the below product have been found to comply with the requirements of the referenced standards at the time the tests were carried out. This verification is part of the full test report and should be read in conjunction with it.

Applicant Name & Address:	SolarEdge Technologies Ltd. 1 HaMada Street, 4673335 Herzliya, Israel
Product Description:	Grid Support Utility Interactive Inverter – Non-Isolated Photovoltaic Inverter with MPPT function, Rapid shut down Function, Arc Fault Protection, Standalone application, and with embedded Supplemental Power Control System
Specifications:	See Appendix 2
Models/Type References:	SE3000H-US, SE3800H-US, SE5000H-US, SE5700H-US, SE6000H-US, SE7600H-US, SE10000H-US, and SE11400H-US
Brand Names:	SolarEdge
Relevant Standard(s) / Specification(s):	See Appendix 1 and 2.
Verification Issuing Office Name & Address:	Intertek Testing Services NA, Inc. 3933 US Route 11, Cortland, NY 13045 USA
Date of Tests:	10/08/2023 to 11/30/2023
Test Report Number(s):	102144760CRT-001e, 104456146CRT-001

Additional information in Appendix.

Signature



Name: Mukund Rana

Position: Sr. Staff Engineer

Initial Issue Date: 4th Jan 2024; Revision Date: May-28th, 2024

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

Appendix 1: Relevant Standard(s)/Specification(s)

Inverters, Converters, Controllers and Interconnection System Equipment for use with Distributed Energy Resources
[UL 1741:2021 Ed.3]

UL 1741 ed 3 3rd Edition CRD on Power Control Systems (PCS) - April 8, 2023

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

Appendix 2: Specifications

Critical Component with its Rating:

Item no.	Name	Manufacturer/ trademark	Type / model	Technical data and securement means	Mark(s) of conformity
1	CT external	SolarEdge	SECT-S1	225A, 0-333mV, 50-60Hz, Accuracy: 1 %, split core clamp design., -40to 140 °F Temp range, Accuracy: sub 1% (SE CT 0.5% CT)	ETL
2	Inverters	SolarEdge	SE3000H-US	3000W, 240V _{AC} , 60HZ, 12.5A _{AC}	cETLus
			SE3800H-US	3800W, 240/208V _{AC} , 60HZ, 16A _{AC}	
			SE5000H-US	5000W, 240/208V _{AC} , 60HZ, 21/24A _{AC}	
			SE5700H-US	5700W, 240/208V _{AC} , 60HZ, 24A _{AC}	
			SE6000H-US	6000W, 240/208V _{AC} , 60HZ, 24/25A _{AC}	
			SE7600H-US	7600W, 240V _{AC} , 60HZ, 32A _{AC}	
			SE10000H-US	10000W, 240/208V _{AC} , 60HZ, 42/48.5A _{AC}	
			SE11400H-US	11400W, 240/208V _{AC} , 60HZ, 47.5/48.5A _{AC}	

➤ PCS Busbar Current Control Feature:

Sr. No.	Model	Maximum Output Current (A) (PCS Limit)
1	SE3000H-US	12.5
2	SE3800H-US	16
3	SE5000H-US	24 @ 208V, 21 @ 240V
4	SE5700H-US	24
5	SE6000H-US	24 @ 208V 25 @ 240V
6	SE7600H-US	32
7	SE10000H-US	42
8	SE11400H-US	48.5 @ 208V 47.5 @ 240V

➤ Inverter Firmware Version:



Version	Checksum
2.100.1302	0x94D2827A
2.0.1305	0xDDF8

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

Appendix 3: Application Description

Application	Standard Sections	Description
Control of the output of a power production source to limit current and loading on a busbar to satisfy NEC 705.13	201; 203.5; 203.6; 205-209; 204.1	Supplemental PCS overcurrent protection used to limit inverter output current to an external reference point. Input from the utility source is monitored while the inverter output current is monitored and controlled not to exceed the ampacity rating of the busbar during changes in load or generation. Inverter input current may be derived from both PV and ESS DC sources.
Control of the output of a power production source to limit current to an external reference point. California Electric Rule 21 Electric Schedule NEM2	-	PCS export limit used to limit the DER output to the area EPS. Open loop response time recorded was less than two seconds.

Appendix 4: Revision Summary

Date / Project	Engineer / Reviewer	Descriptions
May-28-2024 G105788285	Mukund Rana  Lixin Ma 	Updated Inverter Firmware Version. Version is changed from '2.100.1204' to '2.100.1302 and 2.0.1305'. Checksum is updated from '0xFC5866C9' to '0x94D2827A' and '0x94D2827A' Updated Appendix 3 standard section to 204.1

-----END-----

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.