



CERTIFICATE

No. Z2 082496 0034 Rev. 00

Holder of Certificate: SolarEdge Technologies Ltd.

1 Hamada Street 4673335 Herzeliya

ISRAEL

Certification Mark:



Product: Crystalline Silicon Terrestrial Photovoltaic (PV) Modules

Mono-Crystalline Silicon Photovoltaic Module

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: 701262323701-00

Valid until: 2028-05-11

Date, 2023-10-27

(David Bo)



CERTIFICATE

No. Z2 082496 0034 Rev. 00

Model(s): PVxxx-R54PBML, xxx = 385 to 415 in steps of 5

Test Laboratory:

SPVxxx-R54PBML, xxx = 385 to 415 in steps of 5 PVxxx-R54PWML, xxx = 395 to 425 in steps of 5 SPVxxx-R54PWML, xxx = 395 to 425 in steps of 5 PVxxx-R66PBML, xxx = 470 to 505 in steps of 5 PVxxx-R66PWML, xxx = 485 to 515 in steps of 5 xxx is standing for rated output power at STC

Parameters:

Construction: Framed, with Junction box,

Cable and Connectors.
Yangzhou Opto-Electrical
Products Testing Institute

No. 10 West Kaifa Road, Yangzhou

225009 Jiangsu, P. R. China

Safety Class: Class II

Maximum System Voltage: 1000 V DC

Fire Safety Class: Class C according to UL790

Tested IEC 61215-1:2016 IEC 61215-1-1:2016 IEC 61215-1-1:2016 IEC 61215-2:2016

IEC 61215-2:2016 IEC 61730-1:2016 IEC 61730-2:2016 EN IEC 61730-1:2018

EN IEC 61730-1:2018/AC:2018-06

EN IEC 61730-2:2018

EN IEC 61730-2:2018/AC:2018-06

ERTI