

No. 2621/0429-G-CER

By the product certificate number

Issued to:

SolarEdge Technologies Ltd.

1 Hamada street, Herzliya Pituach 4673335, Israel

Trademark:

License holder:

solaredge

Factory location:

SolarEdge Technologies Ltd.

2 Hamerkava street, industrial Zone, Tziporit, Israel

It is certified that the product:

Type of product: Three-Phase Photovoltaic Inverter

Model: **Technical Data:**

Rated Power **Rated Voltage**

Rated Frequency Firmware version Number of phases

Isolation transformer

SE330K

330 kW

690 Vac 50 Hz

2.3.132 **Three Phase**

> (3/N/PE) No

Is in compliance with product requirements of the standard:

EN 50549-2:2019+AM:2023: Requirements for generating plants to be connected in parallel with distribution networks - Part 2: Connection to a MV distribution network - Generating plants up to and including Type B.

Is in compliance with the requirements of regulation:

EN 50549-10:2022: Requirements for generating plants to be connected in parallel with distribution networks - Part 10: Tests for conformity assessment of generating units.

The above-mentioned product is certified according to the standard EN 50549-2:2019+AM:2023 and is valid to be installed in PV generating plants up to and including Type B to be connected to a MV distribution network. The relation between this European Standard with the relevant Article of COMMISSION REGULATION (EU) 2016/631 (NC RfG) is considered as it is indicated in the annex H of the standard EN 50549-2:2019+AM:2023.

Aforementioned equipment is certified according to SGS internal procedure PE.T-ECPE-54 according to requirements established on standard UNE-EN ISO/IEC 17065.

This certificate is first issued on 17th July 2024 This certificate is valid until the 17th July 2029

Madrid, 17th July 2024

for Product Certification at

Daniel Arranz Muñiz Certification Manager











ANNEX I: EN 50549 PARAMETER TABLE

Clause(s) / subclause(s) of EN 50549-2:2019	Parameter	Remarks/ additional information	Configurable value range	Default value
4.4.2 Operating frequency range	47.0 – 47.5 Hz Duration		0 – 20 s	20s
	47.5 – 48.5 Hz Duration	CENTER OF SERVICES	30 – 90 min	90 min
	48.5 – 49.0 Hz Duration		30 – 90 min	90 min
	49.0 – 51.0 Hz Duration		Not configurable	Unlimited
	51.0 – 51.5 Hz Duration		30 – 90 min	90 min
	51. 5 – 52 Hz Duration	Maketas en	0 – 15 min	15 min
4.4.3 Minimal	Reduction threshold		Not configurable	49,5 Hz
requirement for active power delivery at underfrequency	Maximum reduction rate		Not configurable	10 % P _M /Hz
4.4.4 Continuous operating voltage range	Upper limit		Not configurable	110 % Un
	Lower limit		Not configurable	90 % Un
4.5.2 Rate of change of frequency (ROCOF) immunity	ROCOF withstand capability		Not configurable	2 Hz/s





Clause(s) / subclause(s) of EN 50549-2:2019	Parameter	Remarks/ additional information	Configurable value range	Defaul	t value
4.5.3.2 Under-voltage ride through (UVRT) Generating plant	Maximum power resumption time		Not configurable	1 s	
with non-	Voltage-Time-Diagram		See Figure 6 of	Time [s]	U [p.u.
synchronous generating				0,00	0,05
technology				0,25	0,05
			EN 50549-2:2019	3,00	0,85
		50 K (100 C C C C C C C C C C C C C C C C C C	665 (1541) (1654) (1774) 565 (1541) (1774) 565 (1541) (1774)	180	0,85
			50365650565 5630303050 5030305655	180	0,9
4.5.3.3 Under-voltage ride through (UVRT)	Maximum power resumption time		Not configurable	3 s	
Generating plant with	Voltage-TimeDiagram	30 0103 0103 0100 0100 0	9656665 8646666	Time [s]	U [p.u
synchronous generating technology			See Figure 7 of EN 50549-2:2019	N/A	N/A
4.5.4 Over-voltage ride	Voltage-TimeDiagram	NUMBER OF SECRETARIES	Not configurable see Figure 8 of EN 50549-2:2019	Time [s]	U [p.u
through (OVRT)				0,0	1,25
				0,1	1,25
				0,1	1,20
				5,0	1,20
	TOSCION SUMMERS CONTROLS			5,0	1,15
				60	1 15
	\$4500000	PERGRAPHICA DECEMBER	6450 6650 6550	60	1,15





Clause(s) / subclause(s) of EN 50549-2:2019	Parameter	Remarks/ additional information	Configurable value range	Default value
4.6.1 Power response to	Threshold frequency f1		50,2 Hz – 52 Hz	50,2 Hz
overfrequency	Droop	100501 205050505050 1005050505050	2 % – 12 %	5 %
	Power reference		P _M P _{max}	P _{max} , for EESS P _M for other nonsynchronous generating technology
	Intentional delay		0 – 2 s	0s
	Deactivation threshold fstop		50,0 Hz – f1	Deactivated
	Deactivation time tstop		0 – 600 s	· ·
	Acceptance of staged disconnection		Yes No	No
4.6.2 Power response to underfrequency	Threshold frequency f1		49,8 Hz – 46 Hz	49,8 Hz
	Droop		2 – 12 %	5 %
	Power reference		P _M P _{max}	P _{max}
	Intentional delay		0 – 2 s	0 s
4.7.2.2 voltage support by reactive power - Capabilities	Active factor / Reactive power (%Pd) range overexcited		0.1 – 1 / 100 %P _d - 0	0.1 – 1 / 100 %P _d - 0
	Active factor / Reactive power (%Pd) range underexcited		0.1 – 1 / 100 %P _d - 0	0.1 – 1 / 100 %P _d - 0







Clause(s) / subclause(s) of EN 50549-2:2019	Parameter	Remarks/ additional information	Configurable value range	Default	value
4.7.2.3 voltage support by reactive power – Control modes	Enabled control mode		Q setp. Q(U) Q(P)	Q set į	point
4.7.2.3.2 voltage support by reactive	Q set point and excitation		0 – 98.8 % PD	0	
power - Set point control modes	cos φ set point and excitation		N/A	N/A	
4.7.2.3.3 voltage support by reactive power - Voltage related control modes	Characteristic curve			U (%Un) 93% 94% 106% 107%	Q (%Pn +60% 0% 0% -60%
	Time constant		3 s – 60 s	10 s	
	Min cos φ		0,0 – 1	0,9	
	Lock-in power		0 % – 20 %	Deactivated	
	Lock-out power		0 % – 20 %	Deactivated	
4.7.2.3.4 voltage support by reactive power - Power related control mode	Characteristic curve		STREET, SEC. SEC. SEC. SEC. SEC. SEC. SEC. SEC.	P (%Pn) 15% 20% 80% 85%	Q (%Pn +60% 0% 0% -60%
4.7.4.2.1 Voltage support during faults and voltage	Enabling		Enable Disable	Disab	oled
steps – General	Static voltage range overvoltage		100 % U _c – 120 % U _c	110 % U _c	
	Static voltage range undervoltage		80 % U _c – 100 % U _c	90 % U _c	
/ Generating Plant with non-synchronous	Insensitivity range of ΔU50per		0 % – 15 %	5 %	
generator	Gradient k1	ASTRONOMICS PROGRESS	0-6	2	
	Gradient k2	0-0505050505050505050505050505050505050	0-6	2	







Clause(s) / subclause(s) of EN 50549-2:2019	Parameter	Remarks/ additional information	Configurable value range	Default value
4.7.4.2.1.2 Optional	Active power priority		N/A	N/A
Modes / Generating Plant with non-synchronous	Reactive current limitation [% rated current]		0 % - 100 %	Disable
generator	Zero current threshold	Strategy (Part of Strategy)	0 % - 100 %	Disable
4.7.4.2.2 Zero current	Enabling		Enable Disable	Disable
mode for converter connected generating technology	Static voltage range overvoltage		100 % Un – 120 % U _n	120 % U _n
/ Generating Plant with non-synchronous generator	Static voltage range undervoltage		20 % U _n – 100 % U _n	50 % U _n
4.9.3 Requirements on voltage and frequency protection	Threshold for protection as dedicated device [in A or kW. kVA]		N/A	
	Undervoltage threshold stage 1		N/A	
	Undervoltage operate time stage 1		N/A	
	Undervoltage threshold stage 2		N/A	
	Undervoltage operate time stage 2		N/A	
	Overvoltage threshold stage 1		N/A	650 650 6505 6505 6505 6505 6505
	Overvoltage operate time stage 1		N/A	-0.56 CO
	Overvoltage threshold stage 2		N/A	
	Overvoltage operate time stage 2		N/A	





Clause(s) / subclause(s) of EN 50549-2:2019	Parameter	Remarks/ additional information	Configurable value range	Default value
4.9.3 Requirements on voltage and frequency protection	Overvoltage threshold 10 min mean protection		N/A	
	Underfrequency threshold stage 1		N/A	
	Underfrequency operate time stage 1		N/A	
	Underfrequency threshold stage 2		N/A	
	Underfrequency operate time stage 2		N/A	
	Overfrequency threshold stage 1		N/A	
	Overfrequency operate time stage 1		N/A	
	Overfrequency threshold stage 2		N/A	
	Overfrequency operate time stage 2		N/A	
4.10.2 Automatic	Lower frequency	Mark Supplemental Sections	47,0 Hz – 50,0 Hz	49,5 Hz
reconnection after tripping	Upper frequency	PURE SELECTION OF COLUMN	50,0 Hz – 52,0 Hz	50,2 Hz
	Lower voltage		50 % U _c – 100 % U _c	90 % U _c
	Upper voltage	STATE OF THE STATE	100 % U _c – 120 % U _c	110 % U _c
	Observation time	SCHOOL SERVICES	10 s – 600 s	60 s
	Active power increase gradient		6 % - 3000 %/min	10 %/min
4.10.3 Starting to	Lower frequency	WILLIAM CONTROL CONTROL CONTROL	47,0 Hz – 50,0 Hz	49,5 Hz
generate electrical power	Upper frequency	Connection and reconnection Will be	50,0 Hz – 52,0 Hz	50,1 Hz
•	Lower voltage		50 % U _c – 100 % U _c	90 % U _c
	Upper voltage		100 % U _c – 120 % U _c	110 % U _c
	Observation time	performed by an external	10 s - 600 s	60 s
	Active power increase gradient	device	6 % - 3000 %/min	Disabled
4.11.1 Ceasing active power	Activation option		Digital input /	Modbus
4.11.2 Reduction of active power on set point	Activation option		Digital input / Modbus	
4.12 Remote information exchange	Available communication standards	Remote information exchange shall be evaluated according to requirements of DSO/TSO or other interested parties	N/A	



