

Certificate of Conformity

By the product certificate number:

No. 2621/0234/B-E1-CER

Issued to

License holder: **SolarEdge Technologies, Ltd.**
1 Hamada street Herzliya Pituach, 4673335 (Israel)

Trademark:

solaredge

Factory:

Jabil Circuit (Guangzhou) Ltd.
Dev East District 128 Jun Cheng RD, Guangzhou, Guangdong 510530 (China)

It is certified that the product:

Type of generator: Three Phase Inverter

Models:		SE25K	SE30K	SE33.3K	SE50K	SE66.6K	SE90K	SE100K
Technical Data:	Max. real power	25 kW	30 kW	33.3 kW	50 kW	66.6 kW	90 kW	100 kW
	Rated Voltage	230 - 400 V						
	Max. current	36.25 A	43.5 A	48.25 A	72.5 A	96.5 A	130.5 A	145 A
	Rated Frequency	50 - 60 Hz						
	Number of phases	Three Phase						
	Firmware version	Main DSP: 1.20 / Aux DSP: 2.20						

Is in compliance with the standard:

- **Engineering Recommendation G99/N1. Issue 1, April 2019.**
Requirements for the connection of generation equipment in parallel with public distribution networks in Northern Ireland on or after 27 April 2019

The product above-mentioned is certified to be connected in generation systems of type B of both of the above-mentioned certified standards.

This certificate is based upon the test results of the Test Report nº 2221 / 0234-AM1. The testing process has been carried out according the SGS internal procedure PE.T-LE-62 based on the requirements of the UNE-EN ISO / IEC 17025.

The above-mentioned generating unit is certified according to the SGS internal process no. 4 based on the requirements of the UNE-EN ISO/IEC 17065.

This certificate is first issued on: 18th October 2021.

This certificate is valid until: 18th October 2024.

Madrid, 28th July 2022



Daniel Arranz Muñoz
Certification Manager

