

No. 2621/0234/A-CER

Certificate of Conformity

By the product certificate number:

Issued to								
License holder:	SolarEdge Technologies, Ltd. 1 Hamada street Herzliya Pituach 4673335 (Israel)							
Trademark:	solaredge						SGS	
Factory:	Jabil Circuit (Guangzhou) Ltd. Dev East District 128 Jun Cheng RD Guangzhou Guangdong 510530 (China)							
It is certified that the	product:							
Type of generator:	Three Phase Inverter							
Models:		SE25K	SE30K	SE33.3K	SE50K	SE66.6K	SE90K	SE100K
Technical Data:	Max. real power	25 kW	30 kW	33.3 kW	50 kW	66.6 kW	90 kW	100 kW
	Rated Voltage				230 - 400 V			
	Max. current	36.25 A	43.5 A	48.25 A	72.5 A	96.5 A	130.5 A	145 A
	Rated Frequency				50 - 60 Hz			
	Number of phases T				Three Phase			
	Firmware version Main DSP:				: 1.20 / Aux DSP: 2.20			

Is in compliance with the standard:

- Engineering Recommendation G99. Issue 1, Amendment 6. March 2020.

Requirements for the connection of generation equipment in parallel with public distribution networks on or after 27 April 2019.

The product above-mentioned is certified to be connected in generation systems of type B of both of the above-mentioned certified standards.

This certificate is based upon the test results of the Test Report nº 2221 / 0234. The testing process has been carried out according the SGS internal procedure PE.T-LE-62 based on the requirements of the UNE-EN ISO / IEC 17025.

The above-mentioned generating unit is certified according to the SGS internal process no. 4 based on the requirements of the UNE-EN ISO/IEC 17065.

This certificate is first issued on: 18th October 2021. This certificate is valid until: 18th October 2024.

SGS

Madrid, 18th October 2021

Daniel Arranz Muñiz Certification Manager



SGS Tecnos, S.A. C/ Trespaderne, 29 - 28042 Madrid This certificate is issued by SGS under its General Conditions for Product Certification at <u>www.sgs.com/terms_and_conditions</u>. The status and validity of the certificate can be checked scanning the QR code above included or through the following web link database: <u>https://www.sgs.com/en/certified-clients-and-products/electrical-products</u> This document cannot be reproduced partially

No. 2621/0234/A-CER Page 1 of 1