

This authorizes the application of the Certification Mark(s) shown below to the models described in the Product(s) Covered section when made in accordance with the conditions set forth in the Certification Agreement and Listing Report. This authorization also applies to multiple listee model(s) identified on the correlation page of the Listing Report.

This document is the property of Intertek Testing Services and is not transferable. The certification mark(s) may be applied only at the location of the Party Authorized To Apply Mark.

Applicant:

Address:

SolarEdge Technologies Ltd
1 Ha'Mada St.
Herzeliya 4673335

Manufacturer:

Address:

Jabil Circuit (Guangzhou) LTD
DEV EAST DISTRICT
128 JUN CHENG RD
GUANGZHOU
510530
GUANGDONG

Country:

Country:

Israel
China

Party Authorized To Apply Mark:

Report Issuing Office:

Same as Manufacturer
Intertek Testing Services NA, Inc., Cortland, NY

Control Number:

Authorized by:

4004590

L. Matthew Snyder

for L. Matthew Snyder, Certification Manager



This document supersedes all previous Authorizations to Mark for the noted Report Number.

This Authorization to Mark is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Authorization to Mark. Only the Client is authorized to permit copying or distribution of this Authorization to Mark and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement and in this Authorization to Mark. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.

Intertek Testing Services NA Inc.
545 East Algonquin Road, Arlington Heights, IL 60005
Telephone 800-345-3851 or 847-439-5667 Fax 312-283-1672

| | |
|---------------------|--|
| Standard(s): | <p>Inverters, Converters, Controllers and Interconnection System Equipment for use with Distributed Energy Resources [UL 1741:2021 Ed.3]</p> <p>Grid Support Utility Interactive Equipment - Supplement SA to UL 1741:2021 Ed.3 - Inverters, Converters, Controllers and Interconnection System Equipment for use with Distributed Energy Resources [UL 1741:2021 Ed.3 (Supplement SA)]</p> <p>Grid Support Utility Interactive Inverters and Converters Based Upon IEEE 1547:2018 & IEEE 1547.1:2020 - Supplement SB to UL 1741:2021 Ed.3 - Inverters, Converters, Controllers and Interconnection System Equipment for use with Distributed Energy Resources [UL 1741:2021 Ed.3 (Supplement SB)]</p> <p>Power Conversion Equipment (R2021) [CSA C22.2#107.1:2016 Ed.4]</p> <p>Photovoltaic (PV) DC Arc-Fault Circuit Protection [UL 1699B:2018 Ed.1+R:18May2021]</p> <p>Dc Arc Fault Protection For Photovoltaic Applications [CSA C22.2#292:2018 Ed.1]</p> <p>Interconnection of Distributed Energy Resources and Electricity Supply Systems [CSA C22.3#9:2020 Ed.2]</p> <p>Photovoltaic Rapid Shutdown Systems (R2022) [CSA C22.2#330:2017 Ed.1]</p> |
| Product: | Grid support Utility Interactive Inverter - Non Isolated Photovoltaic Inverter with MPPT function and Rapid shut down Function. |
| Brand Name: | SolarEdge |
| Models: | SE followed by 10, 14.4, 16.7, 17.3, 24, 30, 33.3 or 40; followed by KUS. |


This authorizes the application of the Certification Mark(s) shown below to the models described in the Product(s) Covered section when made in accordance with the conditions set forth in the Certification Agreement and Listing Report. This authorization also applies to multiple listee model(s) identified on the correlation page of the Listing Report.

This document is the property of Intertek Testing Services and is not transferable. The certification mark(s) may be applied only at the location of the Party Authorized To Apply Mark.

| | | | |
|-------------------|------------------------------------|----------------------|--|
| Applicant: | SolarEdge Technologies Ltd | Manufacturer: | SolarEdge Technologies Inc |
| Address: | 1 Ha'Mada St. Herzeliya 4673335 | Address: | 447 Ingenuity Avenue Suite 120, Bldg. B, Sparks, NV 89441 |

| | | | |
|-----------------|--------|-----------------|-----|
| Country: | Israel | Country: | USA |
|-----------------|--------|-----------------|-----|

| | |
|--|--|
| Party Authorized To Apply Mark: | Same as Manufacturer |
| Report Issuing Office: | Intertek Testing Services NA, Inc., Cortland, NY |

| | | | |
|------------------------|----------------|-----------------------|--|
| Control Number: | <u>4004590</u> | Authorized by: | <u></u> |
| | | | for L. Matthew Snyder, Certification Manager |



This document supersedes all previous Authorizations to Mark for the noted Report Number.

This Authorization to Mark is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Authorization to Mark. Only the Client is authorized to permit copying or distribution of this Authorization to Mark and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement and in this Authorization to Mark. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.

Intertek Testing Services NA Inc.
545 East Algonquin Road, Arlington Heights, IL 60005
Telephone 800-345-3851 or 847-439-5667 Fax 312-283-1672

| | |
|---------------------|--|
| Standard(s): | <p>Inverters, Converters, Controllers and Interconnection System Equipment for use with Distributed Energy Resources [UL 1741:2021 Ed.3]</p> <p>Grid Support Utility Interactive Equipment - Supplement SA to UL 1741:2021 Ed.3 - Inverters, Converters, Controllers and Interconnection System Equipment for use with Distributed Energy Resources [UL 1741:2021 Ed.3 (Supplement SA)]</p> <p>Grid Support Utility Interactive Inverters and Converters Based Upon IEEE 1547:2018 & IEEE 1547.1:2020 - Supplement SB to UL 1741:2021 Ed.3 - Inverters, Converters, Controllers and Interconnection System Equipment for use with Distributed Energy Resources [UL 1741:2021 Ed.3 (Supplement SB)]</p> <p>Power Conversion Equipment (R2021) [CSA C22.2#107.1:2016 Ed.4]</p> <p>Photovoltaic (PV) DC Arc-Fault Circuit Protection [UL 1699B:2018 Ed.1+R:18May2021]</p> <p>Dc Arc Fault Protection For Photovoltaic Applications [CSA C22.2#292:2018 Ed.1]</p> <p>Interconnection of Distributed Energy Resources and Electricity Supply Systems [CSA C22.3#9:2020 Ed.2]</p> <p>Photovoltaic Rapid Shutdown Systems (R2022) [CSA C22.2#330:2017 Ed.1]</p> |
| Product: | Grid support Utility Interactive Inverter - Non Isolated Photovoltaic Inverter with MPPT function and Rapid shut down Function. |
| Brand Name: | SolarEdge |
| Models: | SE followed by 10, 14.4, 16.7, 17.3, 24, 30, 33.3 or 40; followed by KUS. |

This authorizes the application of the Certification Mark(s) shown below to the models described in the Product(s) Covered section when made in accordance with the conditions set forth in the Certification Agreement and Listing Report. This authorization also applies to multiple listee model(s) identified on the correlation page of the Listing Report.

This document is the property of Intertek Testing Services and is not transferable. The certification mark(s) may be applied only at the location of the Party Authorized To Apply Mark.

Applicant:

SolarEdge Technologies Ltd

Address:

1 Ha'Mada St.
Herzeliya 4673335

Manufacturer:

Flextronics ZALA

Address:

Posta u. 63
Zalaegerszeg 8900

Country:

Israel

Country:

Hungary

Party Authorized To Apply Mark:

Same as Manufacturer

Report Issuing Office:

Intertek Testing Services NA, Inc., Cortland, NY

Control Number:

4004590

Authorized by:


for L. Matthew Snyder, Certification Manager



This document supersedes all previous Authorizations to Mark for the noted Report Number.

This Authorization to Mark is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Authorization to Mark. Only the Client is authorized to permit copying or distribution of this Authorization to Mark and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement and in this Authorization to Mark. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.

Intertek Testing Services NA Inc.
545 East Algonquin Road, Arlington Heights, IL 60005
Telephone 800-345-3851 or 847-439-5667 Fax 312-283-1672

| | |
|---------------------|--|
| Standard(s): | <p>Inverters, Converters, Controllers and Interconnection System Equipment for use with Distributed Energy Resources [UL 1741:2021 Ed.3]</p> <p>Grid Support Utility Interactive Equipment - Supplement SA to UL 1741:2021 Ed.3 - Inverters, Converters, Controllers and Interconnection System Equipment for use with Distributed Energy Resources [UL 1741:2021 Ed.3 (Supplement SA)]</p> <p>Grid Support Utility Interactive Inverters and Converters Based Upon IEEE 1547:2018 & IEEE 1547.1:2020 - Supplement SB to UL 1741:2021 Ed.3 - Inverters, Converters, Controllers and Interconnection System Equipment for use with Distributed Energy Resources [UL 1741:2021 Ed.3 (Supplement SB)]</p> <p>Power Conversion Equipment (R2021) [CSA C22.2#107.1:2016 Ed.4]</p> <p>Photovoltaic (PV) DC Arc-Fault Circuit Protection [UL 1699B:2018 Ed.1+R:18May2021]</p> <p>Dc Arc Fault Protection For Photovoltaic Applications [CSA C22.2#292:2018 Ed.1]</p> <p>Interconnection of Distributed Energy Resources and Electricity Supply Systems [CSA C22.3#9:2020 Ed.2]</p> <p>Photovoltaic Rapid Shutdown Systems (R2022) [CSA C22.2#330:2017 Ed.1]</p> |
| Product: | Grid support Utility Interactive Inverter - Non Isolated Photovoltaic Inverter with MPPT function and Rapid shut down Function. |
| Brand Name: | SolarEdge |
| Models: | SE followed by 10, 14.4, 16.7, 17.3, 24, 30, 33.3 or 40; followed by KUS. |

This authorizes the application of the Certification Mark(s) shown below to the models described in the Product(s) Covered section when made in accordance with the conditions set forth in the Certification Agreement and Listing Report. This authorization also applies to multiple listee model(s) identified on the correlation page of the Listing Report.

This document is the property of Intertek Testing Services and is not transferable. The certification mark(s) may be applied only at the location of the Party Authorized To Apply Mark.

Applicant:

SolarEdge Technologies Ltd

Address:

1 Ha'Mada St.
Herzeliya 4673335

Manufacturer:

Jabil Vietnam Co. Ltd.

Address:

Lot i8-1, Saigon Hi-tech Park, District 9,
HCM City, Vietnam, 70000

Country:

Israel

Country:

Vietnam

Party Authorized To Apply Mark:

Same as Manufacturer


Report Issuing Office:

Intertek Testing Services NA, Inc., Cortland, NY


Control Number:

4004590

Authorized by:



for L. Matthew Snyder, Certification Manager

The image shows the ETL Intertek logo, which consists of a circular emblem with 'ETL' inside, 'C' on the left, and 'US' on the right, with 'LISTED' at the bottom. Below the emblem is the word 'Intertek'.

This document supersedes all previous Authorizations to Mark for the noted Report Number.

This Authorization to Mark is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Authorization to Mark. Only the Client is authorized to permit copying or distribution of this Authorization to Mark and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement and in this Authorization to Mark. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.

Intertek Testing Services NA Inc.

545 East Algonquin Road, Arlington Heights, IL 60005

Telephone 800-345-3851 or 847-439-5667 Fax 312-283-1672

ATM for Report 104663986CRT-001

Page 7 of 10

ATM Issued: 4-Jan-2024

ED 16.3.15 (1-Jul-2022) Mandatory

| | |
|---------------------|--|
| Standard(s): | <p>Inverters, Converters, Controllers and Interconnection System Equipment for use with Distributed Energy Resources [UL 1741:2021 Ed.3]</p> <p>Grid Support Utility Interactive Equipment - Supplement SA to UL 1741:2021 Ed.3 - Inverters, Converters, Controllers and Interconnection System Equipment for use with Distributed Energy Resources [UL 1741:2021 Ed.3 (Supplement SA)]</p> <p>Grid Support Utility Interactive Inverters and Converters Based Upon IEEE 1547:2018 & IEEE 1547.1:2020 - Supplement SB to UL 1741:2021 Ed.3 - Inverters, Converters, Controllers and Interconnection System Equipment for use with Distributed Energy Resources [UL 1741:2021 Ed.3 (Supplement SB)]</p> <p>Power Conversion Equipment (R2021) [CSA C22.2#107.1:2016 Ed.4]</p> <p>Photovoltaic (PV) DC Arc-Fault Circuit Protection [UL 1699B:2018 Ed.1+R:18May2021]</p> <p>Dc Arc Fault Protection For Photovoltaic Applications [CSA C22.2#292:2018 Ed.1]</p> <p>Interconnection of Distributed Energy Resources and Electricity Supply Systems [CSA C22.3#9:2020 Ed.2]</p> <p>Photovoltaic Rapid Shutdown Systems (R2022) [CSA C22.2#330:2017 Ed.1]</p> |
| Product: | Grid support Utility Interactive Inverter - Non Isolated Photovoltaic Inverter with MPPT function and Rapid shut down Function. |
| Brand Name: | SolarEdge |
| Models: | SE followed by 10, 14.4, 16.7, 17.3, 24, 30, 33.3 or 40; followed by KUS. |

This authorizes the application of the Certification Mark(s) shown below to the models described in the Product(s) Covered section when made in accordance with the conditions set forth in the Certification Agreement and Listing Report. This authorization also applies to multiple listee model(s) identified on the correlation page of the Listing Report.

This document is the property of Intertek Testing Services and is not transferable. The certification mark(s) may be applied only at the location of the Party Authorized To Apply Mark.

Applicant:

SolarEdge Technologies Ltd

Address:

1 Ha'Mada St.
Herzeliya 4673335

Manufacturer:

SolarEdge Sella1

Address:

2 Hamerkava St. PO Box 70004 Ziporit
Industrial Zone
Nof Hagalil, 1789058

Country:

Israel

Country:

Israel

Party Authorized To Apply Mark:

Same as Manufacturer


Report Issuing Office:

Intertek Testing Services NA, Inc., Cortland, NY

Control Number:

4004590

Authorized by:


for L. Matthew Snyder, Certification Manager



This document supersedes all previous Authorizations to Mark for the noted Report Number.

This Authorization to Mark is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Authorization to Mark. Only the Client is authorized to permit copying or distribution of this Authorization to Mark and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement and in this Authorization to Mark. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.

Intertek Testing Services NA Inc.
545 East Algonquin Road, Arlington Heights, IL 60005
Telephone 800-345-3851 or 847-439-5667 Fax 312-283-1672

| | |
|---------------------|--|
| Standard(s): | <p>Inverters, Converters, Controllers and Interconnection System Equipment for use with Distributed Energy Resources [UL 1741:2021 Ed.3]</p> <p>Grid Support Utility Interactive Equipment - Supplement SA to UL 1741:2021 Ed.3 - Inverters, Converters, Controllers and Interconnection System Equipment for use with Distributed Energy Resources [UL 1741:2021 Ed.3 (Supplement SA)]</p> <p>Grid Support Utility Interactive Inverters and Converters Based Upon IEEE 1547:2018 & IEEE 1547.1:2020 - Supplement SB to UL 1741:2021 Ed.3 - Inverters, Converters, Controllers and Interconnection System Equipment for use with Distributed Energy Resources [UL 1741:2021 Ed.3 (Supplement SB)]</p> <p>Power Conversion Equipment (R2021) [CSA C22.2#107.1:2016 Ed.4]</p> <p>Photovoltaic (PV) DC Arc-Fault Circuit Protection [UL 1699B:2018 Ed.1+R:18May2021]</p> <p>Dc Arc Fault Protection For Photovoltaic Applications [CSA C22.2#292:2018 Ed.1]</p> <p>Interconnection of Distributed Energy Resources and Electricity Supply Systems [CSA C22.3#9:2020 Ed.2]</p> <p>Photovoltaic Rapid Shutdown Systems (R2022) [CSA C22.2#330:2017 Ed.1]</p> |
| Product: | Grid support Utility Interactive Inverter - Non Isolated Photovoltaic Inverter with MPPT function and Rapid shut down Function. |
| Brand Name: | SolarEdge |
| Models: | SE followed by 10, 14.4, 16.7, 17.3, 24, 30, 33.3 or 40; followed by KUS. |