

## Declaration of Identity

This is to declare that the SE20.1K model has identical Hardware as models SE25K,27.6K,33.3K. The output power is controlled by software parameters and all safety tests, conducted according to IEC 62109-1, apply to SE20.1K model as well.

SE25K,27.6K,33.3K 3Ph Inverters are certified according to IEC 62109-1 by BUREAU VERITAS , 3<sup>rd</sup> party lab:

Certificate Number: U18-0615


Report Number:14<sup>TH</sup>0476-IEC62109-1\_7

Herzeliya  
Israel

May 2020

PLACE

Date

  
(Meir Adest, VP Core technologies)