

Three Phase Inverter with Synergy Technology

For the 277/480V Grid for North America
(Ground Mount Installation)

SE110KUS / SE120KUS



Powered by unique pre-commissioning process for rapid system installation

- Pre-commissioning feature for automated validation of system components and wiring during the site installation process and prior to grid connection
- Easy 2-person installation with lightweight, modular design (each inverter consists of 3 Synergy units and 1 Synergy Manager)
- Independent operation of each Synergy unit enables higher uptime and easy serviceability
- Built-in thermal sensors detect faulty wiring ensuring enhanced protection and safety
- Built-in arc fault protection
- Built-in PID mitigation for maximized system performance
- Monitored* and field-replaceable surge protection devices, to better withstand surges caused by lightning or other events
- Built-in module-level monitoring with Ethernet or cellular communication for full system visibility

/ Three Phase Inverter with Synergy Technology

For the 277/480V Grid for North America (Ground Mount Installation)

SE110KUS / SE120KUS

| MODEL NUMBER | SE110K | SE120K | UNITS |
|--|--|--------|-------|
| OUTPUT | | | |
| Rated AC Active Output Power | 110000 | 120000 | W |
| Maximum AC Apparent Output Power | 120000 | 120000 | VA |
| AC Output Line Connections | 3W + PE, 4W + PE | | |
| Supported Grids | WYE: TN-C, TN-S, TN-C-S, TT, IT; Delta: IT | | |
| AC Output Voltage Minimum-Nominal-Maximum ⁽¹⁾ (L-N) | 244 – 277 – 305 | | Vac |
| AC Output Voltage Minimum-Nominal-Maximum ⁽¹⁾ (L-L) | 422.5 – 480 – 529 | | Vac |
| AC Frequency Min-Nom-Max ⁽¹⁾ | 59.5 – 60 – 60.5 | | Hz |
| Maximum Continuous Output Current (per Phase, PF=1) | 144.3 | | Aac |
| GFDI Threshold | 1 | | A |
| Utility Monitoring, Islanding Protection, Configurable Power Factor, Country Configurable Thresholds | Yes | | |
| Total Harmonic Distortion | ≤ 3 | | % |
| Power Factor Range | +/-0.2 to 1 | | |
| INPUT | | | |
| Maximum DC Power (Module STC) Inverter / Synergy Unit | 210000 / 70000 | | W |
| Transformer-less, Ungrounded | Yes | | |
| Maximum Input Voltage DC+ to DC- | 1000 | | Vdc |
| Operating Voltage Range | 840 – 1000 | | Vdc |
| Maximum Input Current | 3 x 48.25 | | Adc |
| Reverse-Polarity Protection | Yes | | |
| Ground-Fault Isolation Detection | 167kΩ sensitivity per Synergy Unit ⁽²⁾ | | |
| CEC Weighted Efficiency | 98.5 | | % |
| Nighttime Power Consumption | < 12 | | W |
| ADDITIONAL FEATURES | | | |
| Supported Communication Interfaces ⁽³⁾ | 2 x RS485, Ethernet, Wi-Fi (optional), Cellular (optional) | | |
| Smart Energy Management | Export Limitation | | |
| Inverter Commissioning | With the SetApp mobile application using built-in Wi-Fi access point for local connection | | |
| Arc Fault Protection | Built-in, User Configurable (According to UL1699B) | | |
| PID Rectifier | Nighttime, built-in | | |
| RS485 Surge Protection (ports 1+2) | Type II, field replaceable, integrated | | |
| AC, DC Surge Protection | Type II, field replaceable, integrated | | |
| DC SAFETY SWITCH | | | |
| DC Disconnect | Built-in | | |
| STANDARD COMPLIANCE | | | |
| Safety | UL1699B, UL1741, UL1741 SA, UL1741 SB, UL1998, CSA C22.2#107.1, Canadian AFCI according to T.I.L. M-07 | | |
| Grid Connection Standards | IEEE 1547-2018, Rule 21, Rule 14 (HI) | | |
| Emissions | FCC part 15 class A | | |

(1) For other regional settings please contact SolarEdge support.

(2) Where permitted by local regulations.

(3) For specifications of the optional communication options, visit the [Communication product page](#) or the [Resource Library](#) to download the relevant product datasheet.

/ Three Phase Inverter with Synergy Technology

For the 277/480V Grid for North America (Ground Mount Installation)

SE110KUS / SE120KUS

| MODEL NUMBER | SE110K | SE120K | UNITS |
|--------------------------------------|---|--------|---------|
| INSTALLATION SPECIFICATIONS | | | |
| Number of Synergy Units per Inverter | 3 | | |
| AC Max Conduit Size | 2 1/2" | | in |
| Max AC AWG Line / PE | 4/0 / 1/0 | | |
| DC Max Conduit Size | 1 x 3"; 2 x 2" | | in |
| DC Inputs Inverter / Synergy Unit | 12 / 4 pairs; 6 – 12 AWG | | |
| | 3 pairs / 1 pair, Max 2 AWG; copper or aluminum | | |
| Dimensions (H x W x D) | Synergy Unit: 22 x 12.9 x 10.75 / 558 x 328 x 273 Synergy Manager: 14.17 x 22.4 x 11.6 / 360 x 560 x 295 | | in / mm |
| Weight | Synergy Unit: 70.4 / 32 Synergy Manager: 39.6 / 18 | | lb / kg |
| Operating Temperature Range | -40 to +140 / -40 to +60 ⁽⁴⁾ | | °F / °C |
| Cooling | Fan (user replaceable) | | |
| Noise | < 67 | | dBA |
| Protection Rating | NEMA 3R | | |
| Mounting | Brackets provided | | |

(4) For power de-rating information refer to the [Temperature De-rating - Technical Note \(North America\)](#).

SolarEdge is a global leader in smart energy technology. By leveraging world-class engineering capabilities and with a relentless focus on innovation, SolarEdge creates smart energy solutions that power our lives and drive future progress.

SolarEdge developed an intelligent inverter solution that changed the way power is harvested and managed in photovoltaic (PV) systems. The SolarEdge DC optimized inverter maximizes power generation while lowering the cost of energy produced by the PV system.

Continuing to advance smart energy, SolarEdge addresses a broad range of energy market segments through its PV, storage, EV charging, UPS, and grid services solutions.

-  SolarEdge
-  @SolarEdgePV
-  @SolarEdgePV
-  SolarEdgePV
-  SolarEdge
-  www.solaredge.com/corporate/contact

solaredge.com

© SolarEdge Technologies, Ltd. All rights reserved. SOLAREEDGE, the SolarEdge logo, OPTIMIZED BY SOLAREEDGE are trademarks or registered trademarks of SolarEdge Technologies, Inc. All other trademarks mentioned herein are trademarks of their respective owners. Date: November 27, 2022 DS-000021-NAM Subject to change without notice.

Cautionary Note Regarding Market Data and Industry Forecasts: This brochure may contain market data and industry forecasts from certain third-party sources. This information is based on industry surveys and the preparer's expertise in the industry and there can be no assurance that any such market data is accurate or that any such industry forecasts will be achieved. Although we have not independently verified the accuracy of such market data and industry forecasts, we believe that the market data is reliable and that the industry forecasts are reasonable.

