

This authorizes the application of the Certification Mark(s) shown below to the models described in the Product(s) Covered section when made in accordance with the conditions set forth in the Certification Agreement and Listing Report. This authorization also applies to multiple listee model(s) identified on the correlation page of the Listing Report.

This document is the property of Intertek Testing Services and is not transferable. The certification mark(s) may be applied only at the location of the Party Authorized To Apply Mark.

Applicant: SolarEdge Technologies Ltd

Manufacturer: Jabil Circuit (Guangzhou) LTD

Address: 1 Ha'Mada St.
Herzeliya 4673335

Address: 128 JUN CHENG RD
Guangzhou Economic & Tech Dev
District, GUANGZHOU
GUANGDONG 510530

Country: Israel

Country: China

Party Authorized To Apply Mark: Same as Manufacturer
Report Issuing Office: Intertek Testing Services NA, Inc., Cortland, NY

Control Number: 4004590

Authorized by:



for L. Matthew Snyder, Certification Manager



This document supersedes all previous Authorizations to Mark for the noted Report Number.


This Authorization to Mark is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Authorization to Mark. Only the Client is authorized to permit copying or distribution of this Authorization to Mark and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement and in this Authorization to Mark. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.

Intertek Testing Services NA Inc.
545 East Algonquin Road, Arlington Heights, IL 60005
Telephone 800-345-3851 or 847-439-5667 Fax 312-283-1672

Standard(s):	<p>Inverters, Converters, Controllers and Interconnection System Equipment for use with Distributed Energy Resources [UL 1741:2021 Ed.3]</p> <p>Grid Support Utility Interactive Equipment - Supplement SA to UL 1741:2021 Ed.3 - Inverters, Converters, Controllers and Interconnection System Equipment for use with Distributed Energy Resources [UL 1741:2021 Ed.3 (Supplement SA)]</p> <p>Grid Support Utility Interactive Inverters and Converters Based Upon IEEE 1547:2018 & IEEE 1547.1:2020 - Supplement SB to UL 1741:2021 Ed.3 - Inverters, Converters, Controllers and Interconnection System Equipment for use with Distributed Energy Resources [UL 1741:2021 Ed.3 (Supplement SB)]</p> <p>Power Conversion Equipment [CSA C22.2#107.1:2016 Ed.4]</p> <p>Photovoltaic (PV) DC Arc-Fault Circuit Protection [UL 1699B:2018 Ed.1+R:18May2021]</p> <p>Interconnection of Distributed Energy Resources and Electricity Supply Systems [CSA C22.3#9:2020 Ed.2]</p> <p>Photovoltaic Rapid Shutdown Systems [CSA C22.2#330:2017 Ed.1]</p>
Product:	Grid support Utility Interactive Inverter system
Brand Name:	SolarEdge
Models:	SE followed by 43.2 or 50 or 66.6 or 80 or 85 or 90 or 100 or 110 or 120; followed by KUS.

This authorizes the application of the Certification Mark(s) shown below to the models described in the Product(s) Covered section when made in accordance with the conditions set forth in the Certification Agreement and Listing Report. This authorization also applies to multiple listee model(s) identified on the correlation page of the Listing Report.

This document is the property of Intertek Testing Services and is not transferable. The certification mark(s) may be applied only at the location of the Party Authorized To Apply Mark.

Applicant:	SolarEdge Technologies Ltd	Manufacturer:	SolarEdge Technologies Inc
Address:	1 Ha'Mada St. Herzeliya 4673335	Address:	447 Ingenuity Avenue Suite 120, Bldg. B, Sparks, NV 89441
Country:	Israel	Country:	USA
Party Authorized To Apply Mark:	Same as Manufacturer		
Report Issuing Office:	Intertek Testing Services NA, Inc., Cortland, NY		
Control Number:	<u>4004590</u>	Authorized by:	 for L. Matthew Snyder, Certification Manager



This document supersedes all previous Authorizations to Mark for the noted Report Number.

This Authorization to Mark is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Authorization to Mark. Only the Client is authorized to permit copying or distribution of this Authorization to Mark and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement and in this Authorization to Mark. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.

Intertek Testing Services NA Inc.
545 East Algonquin Road, Arlington Heights, IL 60005
Telephone 800-345-3851 or 847-439-5667 Fax 312-283-1672

Standard(s):	<p>Inverters, Converters, Controllers and Interconnection System Equipment for use with Distributed Energy Resources [UL 1741:2021 Ed.3]</p> <p>Grid Support Utility Interactive Equipment - Supplement SA to UL 1741:2021 Ed.3 - Inverters, Converters, Controllers and Interconnection System Equipment for use with Distributed Energy Resources [UL 1741:2021 Ed.3 (Supplement SA)]</p> <p>Grid Support Utility Interactive Inverters and Converters Based Upon IEEE 1547:2018 & IEEE 1547.1:2020 - Supplement SB to UL 1741:2021 Ed.3 - Inverters, Converters, Controllers and Interconnection System Equipment for use with Distributed Energy Resources [UL 1741:2021 Ed.3 (Supplement SB)]</p> <p>Power Conversion Equipment [CSA C22.2#107.1:2016 Ed.4]</p> <p>Photovoltaic (PV) DC Arc-Fault Circuit Protection [UL 1699B:2018 Ed.1+R:18May2021]</p> <p>Interconnection of Distributed Energy Resources and Electricity Supply Systems [CSA C22.3#9:2020 Ed.2]</p> <p>Photovoltaic Rapid Shutdown Systems [CSA C22.2#330:2017 Ed.1]</p>
Product:	Grid support Utility Interactive Inverter system
Brand Name:	SolarEdge
Models:	SE followed by 43.2 or 50 or 66.6 or 80 or 85 or 90 or 100 or 110 or 120; followed by KUS.

This authorizes the application of the Certification Mark(s) shown below to the models described in the Product(s) Covered section when made in accordance with the conditions set forth in the Certification Agreement and Listing Report. This authorization also applies to multiple listee model(s) identified on the correlation page of the Listing Report.

This document is the property of Intertek Testing Services and is not transferable. The certification mark(s) may be applied only at the location of the Party Authorized To Apply Mark.

Applicant: SolarEdge Technologies Ltd

Manufacturer: Flextronics ZALA

Address: 1 Ha'Mada St.
Herzeliya 4673335

Address: Posta u. 63
Zalaegerszeg 8900

Country: Israel

Country: Hungary

Party Authorized To Apply Mark: Same as Manufacturer
Report Issuing Office: Intertek Testing Services NA, Inc., Cortland, NY

Control Number: 4004590

Authorized by:



for L. Matthew Snyder, Certification Manager



This document supersedes all previous Authorizations to Mark for the noted Report Number.

This Authorization to Mark is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Authorization to Mark. Only the Client is authorized to permit copying or distribution of this Authorization to Mark and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement and in this Authorization to Mark. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.

Intertek Testing Services NA Inc.
545 East Algonquin Road, Arlington Heights, IL 60005
Telephone 800-345-3851 or 847-439-5667 Fax 312-283-1672

Standard(s):	<p>Inverters, Converters, Controllers and Interconnection System Equipment for use with Distributed Energy Resources [UL 1741:2021 Ed.3]</p> <p>Grid Support Utility Interactive Equipment - Supplement SA to UL 1741:2021 Ed.3 - Inverters, Converters, Controllers and Interconnection System Equipment for use with Distributed Energy Resources [UL 1741:2021 Ed.3 (Supplement SA)]</p> <p>Grid Support Utility Interactive Inverters and Converters Based Upon IEEE 1547:2018 & IEEE 1547.1:2020 - Supplement SB to UL 1741:2021 Ed.3 - Inverters, Converters, Controllers and Interconnection System Equipment for use with Distributed Energy Resources [UL 1741:2021 Ed.3 (Supplement SB)]</p> <p>Power Conversion Equipment [CSA C22.2#107.1:2016 Ed.4]</p> <p>Photovoltaic (PV) DC Arc-Fault Circuit Protection [UL 1699B:2018 Ed.1+R:18May2021]</p> <p>Interconnection of Distributed Energy Resources and Electricity Supply Systems [CSA C22.3#9:2020 Ed.2]</p> <p>Photovoltaic Rapid Shutdown Systems [CSA C22.2#330:2017 Ed.1]</p>
Product:	Grid support Utility Interactive Inverter system
Brand Name:	SolarEdge
Models:	SE followed by 43.2 or 50 or 66.6 or 80 or 85 or 90 or 100 or 110 or 120; followed by KUS.

This authorizes the application of the Certification Mark(s) shown below to the models described in the Product(s) Covered section when made in accordance with the conditions set forth in the Certification Agreement and Listing Report. This authorization also applies to multiple listee model(s) identified on the correlation page of the Listing Report.

This document is the property of Intertek Testing Services and is not transferable. The certification mark(s) may be applied only at the location of the Party Authorized To Apply Mark.

Applicant: SolarEdge Technologies Ltd

Manufacturer: Jabil Vietnam Co., Ltd.

Address: 1 Ha'Mada St.
Herzeliya 4673335

Address: Lot i8-1, Saigon Hi-tech Park, District 9,
HCM City, Vietnam, 70000

Country: Israel

Country: Vietnam

Party Authorized To Apply Mark: Same as Manufacturer
Report Issuing Office: Intertek Testing Services NA, Inc., Cortland, NY

Control Number: 4004590

Authorized by:



for L. Matthew Snyder, Certification Manager



This document supersedes all previous Authorizations to Mark for the noted Report Number.

This Authorization to Mark is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Authorization to Mark. Only the Client is authorized to permit copying or distribution of this Authorization to Mark and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement and in this Authorization to Mark. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.

Intertek Testing Services NA Inc.
545 East Algonquin Road, Arlington Heights, IL 60005
Telephone 800-345-3851 or 847-439-5667 Fax 312-283-1672

Standard(s):	<p>Inverters, Converters, Controllers and Interconnection System Equipment for use with Distributed Energy Resources [UL 1741:2021 Ed.3]</p> <p>Grid Support Utility Interactive Equipment - Supplement SA to UL 1741:2021 Ed.3 - Inverters, Converters, Controllers and Interconnection System Equipment for use with Distributed Energy Resources [UL 1741:2021 Ed.3 (Supplement SA)]</p> <p>Grid Support Utility Interactive Inverters and Converters Based Upon IEEE 1547:2018 & IEEE 1547.1:2020 - Supplement SB to UL 1741:2021 Ed.3 - Inverters, Converters, Controllers and Interconnection System Equipment for use with Distributed Energy Resources [UL 1741:2021 Ed.3 (Supplement SB)]</p> <p>Power Conversion Equipment [CSA C22.2#107.1:2016 Ed.4]</p> <p>Photovoltaic (PV) DC Arc-Fault Circuit Protection [UL 1699B:2018 Ed.1+R:18May2021]</p> <p>Interconnection of Distributed Energy Resources and Electricity Supply Systems [CSA C22.3#9:2020 Ed.2]</p> <p>Photovoltaic Rapid Shutdown Systems [CSA C22.2#330:2017 Ed.1]</p>
Product:	Grid support Utility Interactive Inverter system
Brand Name:	SolarEdge
Models:	SE followed by 43.2 or 50 or 66.6 or 80 or 85 or 90 or 100 or 110 or 120; followed by KUS.

This authorizes the application of the Certification Mark(s) shown below to the models described in the Product(s) Covered section when made in accordance with the conditions set forth in the Certification Agreement and Listing Report. This authorization also applies to multiple listee model(s) identified on the correlation page of the Listing Report.

This document is the property of Intertek Testing Services and is not transferable. The certification mark(s) may be applied only at the location of the Party Authorized To Apply Mark.

Applicant: SolarEdge Technologies Ltd

Manufacturer: SolarEdge Technologies Inc

Address: 1 Ha'Mada St.
Herzeliya 4673335

Address: 700 E. Tasman Drive,
Milpitas, Ca 95035

Country: Israel

Country: USA

Party Authorized To Apply Mark: Same as Manufacturer
Report Issuing Office: Intertek Testing Services NA, Inc., Cortland, NY

Control Number: 4004590

Authorized by:



for L. Matthew Snyder, Certification Manager



This document supersedes all previous Authorizations to Mark for the noted Report Number.


This Authorization to Mark is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Authorization to Mark. Only the Client is authorized to permit copying or distribution of this Authorization to Mark and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement and in this Authorization to Mark. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.

Intertek Testing Services NA Inc.
545 East Algonquin Road, Arlington Heights, IL 60005
Telephone 800-345-3851 or 847-439-5667 Fax 312-283-1672

Standard(s):	<p>Inverters, Converters, Controllers and Interconnection System Equipment for use with Distributed Energy Resources [UL 1741:2021 Ed.3]</p> <p>Grid Support Utility Interactive Equipment - Supplement SA to UL 1741:2021 Ed.3 - Inverters, Converters, Controllers and Interconnection System Equipment for use with Distributed Energy Resources [UL 1741:2021 Ed.3 (Supplement SA)]</p> <p>Grid Support Utility Interactive Inverters and Converters Based Upon IEEE 1547:2018 & IEEE 1547.1:2020 - Supplement SB to UL 1741:2021 Ed.3 - Inverters, Converters, Controllers and Interconnection System Equipment for use with Distributed Energy Resources [UL 1741:2021 Ed.3 (Supplement SB)]</p> <p>Power Conversion Equipment [CSA C22.2#107.1:2016 Ed.4]</p> <p>Photovoltaic (PV) DC Arc-Fault Circuit Protection [UL 1699B:2018 Ed.1+R:18May2021]</p> <p>Interconnection of Distributed Energy Resources and Electricity Supply Systems [CSA C22.3#9:2020 Ed.2]</p> <p>Photovoltaic Rapid Shutdown Systems [CSA C22.2#330:2017 Ed.1]</p>
Product:	Grid support Utility Interactive Inverter system
Brand Name:	SolarEdge
Models:	SE followed by 43.2 or 50 or 66.6 or 80 or 85 or 90 or 100 or 110 or 120; followed by KUS.

This authorizes the application of the Certification Mark(s) shown below to the models described in the Product(s) Covered section when made in accordance with the conditions set forth in the Certification Agreement and Listing Report. This authorization also applies to multiple listee model(s) identified on the correlation page of the Listing Report.

This document is the property of Intertek Testing Services and is not transferable. The certification mark(s) may be applied only at the location of the Party Authorized To Apply Mark.

Applicant: SolarEdge Technologies Ltd	Manufacturer: Flextronics Manufacturing Mex, S.A de C.V.
Address: 1 Ha'Mada St. Herzeliya 4673335	Address: Carretara base aerea #5850-12 Col. La mora Zapopan Jalisco, Mexico C.P. 45136
Country: Israel	Country: Mexico
Party Authorized To Apply Mark: Same as Manufacturer	
Report Issuing Office: Intertek Testing Services NA, Inc., Cortland, NY	
Control Number: <u>4004590</u>	Authorized by:  for L. Matthew Snyder, Certification Manager



This document supersedes all previous Authorizations to Mark for the noted Report Number.

This Authorization to Mark is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Authorization to Mark. Only the Client is authorized to permit copying or distribution of this Authorization to Mark and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement and in this Authorization to Mark. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.

Intertek Testing Services NA Inc.
545 East Algonquin Road, Arlington Heights, IL 60005
Telephone 800-345-3851 or 847-439-5667 Fax 312-283-1672

Standard(s):	<p>Inverters, Converters, Controllers and Interconnection System Equipment for use with Distributed Energy Resources [UL 1741:2021 Ed.3]</p> <p>Grid Support Utility Interactive Equipment - Supplement SA to UL 1741:2021 Ed.3 - Inverters, Converters, Controllers and Interconnection System Equipment for use with Distributed Energy Resources [UL 1741:2021 Ed.3 (Supplement SA)]</p> <p>Grid Support Utility Interactive Inverters and Converters Based Upon IEEE 1547:2018 & IEEE 1547.1:2020 - Supplement SB to UL 1741:2021 Ed.3 - Inverters, Converters, Controllers and Interconnection System Equipment for use with Distributed Energy Resources [UL 1741:2021 Ed.3 (Supplement SB)]</p> <p>Power Conversion Equipment [CSA C22.2#107.1:2016 Ed.4]</p> <p>Photovoltaic (PV) DC Arc-Fault Circuit Protection [UL 1699B:2018 Ed.1+R:18May2021]</p> <p>Interconnection of Distributed Energy Resources and Electricity Supply Systems [CSA C22.3#9:2020 Ed.2]</p> <p>Photovoltaic Rapid Shutdown Systems [CSA C22.2#330:2017 Ed.1]</p>
Product:	Grid support Utility Interactive Inverter system
Brand Name:	SolarEdge
Models:	SE followed by 43.2 or 50 or 66.6 or 80 or 85 or 90 or 100 or 110 or 120; followed by KUS.