

Certificate of compliance

Applicant: SolarEdge Technologies Ltd.

1 HaMada Street Herzeliya 4673335

Israel

Product: Grid tied Battery based & PV inverter

Model: SE2200H SE6000H

SE4000H SE5000H SE10000H

Use in accordance with regulations:

Automatic disconnection device with single-phase mains surveillance in accordance with NRS 097-2-1:2017 for photovoltaic and battery systems with a single-phase parallel coupling via an inverter in the public mains supply. The automatic disconnection device is an integral part of the aforementioned inverters.

Applied rules and standards:

NRS 097-2-1:2017 Edition 2.1

Grid interconnection of embedded generation, Part 2: Small-scale embedded generation, Section 1: Utility interface Comply with:

Category A1: 0 – 13,8 kVA IEC 61727:2004 Edition 2

Photovoltaic (PV) systems - Characteristics of the utility interface

IEC 62116:2008 Edition 1 / IEC 62116:2014 Edition 2

Test procedure of islanding prevention measures for utility-interconnected photovoltaic inverters

VDE AR-N 4105:2011-08 (A.6 General requirements, single-fault tolerance)

Power generation systems connected to the low-voltage distribution network

Note:

Certificate number:

The inverters are comply with IEC/EN 61000-6-2 "Electromagnetic compatibility (EMC) – Part 6-2: Generic standards – Immunity standard for industrial environments, commercial and light-industrial" and IEC/EN 61000-2-2 "Environment - Compatibility levels for low-frequency conducted disturbances and signalling in public low-voltage power supply systems"

At the time of issue of this certificate the safety concept of an aforementioned representative product corresponds to the valid safety specifications for the specified use in accordance with regulations.

Certification body

Report number: 16TH0371-NRS 097-2-1_2

U23-0587

Certification scheme: NSOP-0032-DEU-ZE-V01

Date of issue: 2023-07-13

DAKKS

Deutsche
Akkreditierungsstelle
D-ZE-12024-01-00

Certification body Bureau Veritas Consumer Products Services Germany GmbH accredited according to DIN EN ISO/IEC 17065

Testing laboratory accredited according to DIN EN ISO/IEC 17025

A partial representation of the certificate requires the written permission of Bureau Veritas Consumer Products Services Germany GmbH